

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (MW) (B)		
1	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
2	TPC U-8	1	96	294	187	17	AS PER SYSTEM CONDITION
3	DTPS REL U-1 AND U-2	1	96	459	336	122	AS PER SYSTEM CONDITION
4	NASK U-3,4 AND 5	1	96	325	264	41	AS PER SYSTEM CONDITION
5	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
6	PARALI U-6 AND U-7	X	X	X	X	X	UNIT-7, UNIT-6 WIDN FOR ZERO SCHEDULE B Y MSEDCL
7	RATTANNIDA U-1 TO U-5	1	24	490	344	146	AS PER SYSTEM CONDITION UNIT-1 AND UNIT-4 SHUT DOWN UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL AT 00HRS OF 26/06/2018
		41	46	490	344	146	AS PER SYSTEM CONDITION UNIT-1 AND UNIT-4 SHUT DOWN UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL AT 00HRS OF 26/06/2018
		55	56	490	344	146	AS PER SYSTEM CONDITION UNIT-1 AND UNIT-4 SHUT DOWN UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL AT 00HRS OF 26/06/2018
		64	69	490	344	146	AS PER SYSTEM CONDITION UNIT-1 AND UNIT-4 SHUT DOWN UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL AT 00HRS OF 26/06/2018
		81	96	490	344	146	AS PER SYSTEM CONDITION UNIT-1 AND UNIT-4 SHUT DOWN UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL AT 00HRS OF 26/06/2018
8	PARALI U-8	1	24	140	X	X	D.C. TECH MIN
		41	45	140	X	X	D.C. TECH MIN
		84	96	140	X	X	D.C. TECH MIN
9	BHUSWAL U-4 AND U-5	1	24	940	644	296	AS PER SYSTEM CONDITION
		41	45	752	644	108	AS PER SYSTEM CONDITION
		84	96	752	644	108	AS PER SYSTEM CONDITION
10	SEPL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
11	DHARNVAL TO MSEDCL	1	24	185	140	45	AS PER SYSTEM CONDITION
		41	45	185	140	45	AS PER SYSTEM CONDITION
		84	96	185	140	45	AS PER SYSTEM CONDITION
12	PARAS U-3 BU-4	1	24	325	X	X	D.C. BELOW TECH MIN
		41	45	222	X	X	D.C. BELOW TECH MIN
		84	96	304	X	X	D.C. BELOW TECH MIN
13	VPL U1 &2	1	24	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		41	44	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		84	96	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-1 TO U-4	1	24	378	X	X	D.C. BELOW TECH MIN UNIT-4 SHUT DOWN
		41	44	378	X	X	D.C. BELOW TECH MIN UNIT-4 SHUT DOWN
		87	96	378	X	X	D.C. BELOW TECH MIN UNIT-4 SHUT DOWN
15	ADANI (TIRODA 440MW PPA) U1, &5	1	24	25	0	25	AS PER SYSTEM CONDITION
		41	44	25	0	25	AS PER SYSTEM CONDITION
		89	96	91	24	67	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-5	X	X	X	X	X	UNIT SHUT DOWN
17	KORADI U-6 BU-7	X	X	X	X	X	UNIT -6 AND UNIT-7 SHUT DOWN
18	ADANI U-1(1200+125)MW PP	1	24	527	432	95	AS PER SYSTEM CONDITION
		41	44	527	432	95	AS PER SYSTEM CONDITION
		89	96	493	432	66	AS PER SYSTEM CONDITION
19	ADANI U-4(1200+125)MW PP	1	24	527	432	95	AS PER SYSTEM CONDITION
		41	44	527	432	95	AS PER SYSTEM CONDITION
		89	96	493	432	66	AS PER SYSTEM CONDITION
20	ADANI U-5(1200+125)MW PP	X	X	X	X	X	UNIT-5 SYN. D.C. BELOW TECH MIN
21	CHANDRAPUR U-3 TO U-7	1	23	1116	968	128	AS PER SYSTEM CONDITION UNIT-3 UNIT-4 SHUT DOWN
		42	44	1059	968	71	AS PER SYSTEM CONDITION UNIT-3 UNIT-4 SHUT DOWN
		93	96	1059	968	71	AS PER SYSTEM CONDITION UNIT-3 UNIT-4 SHUT DOWN
22	JSW U-1	1	23	287	200	87	AS PER SYSTEM CONDITION
		93	96	278	200	78	AS PER SYSTEM CONDITION
23	KORADI U-8 BU-9 &10	8	17	664	X	X	UNIT-8 SHUT DOWN D.C. BELOW TECH MIN
		93	96	609	X	X	UNIT-8 SHUT DOWN D.C. BELOW TECH MIN
24	CHANDRAPUR U-8 BU-9	8	12	474	329	145	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
		93	96	445	329	116	UNIT-9 SHUT DOWN AS PER SYSTEM CONDITION
25	ADANI U-2	X	X	X	X	X	NO BACK DOWN
26	ADANI U-3	X	X	X	X	X	NO BACK DOWN

D.C. BELOW TECH

Note: 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
2 M.O.D. RATES REVISED FROM DT. 12THJUNE2018
3 # Indicates that back down withdrawn due to Line loading/system constraints.