

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	30	516	425	91	DUE TO SYSTEM CONDITION
		80	96				
3	PARALI 3,4,5	1	30	302	276	26	DUE TO SYSTEM CONDITION
		80	96				
4	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	SCH.GIVEN FROM BLK(41-76)
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	1	30	473	292	181	DUE TO SYSTEM CONDITION
		80	96				
7	TPC U-8	1	24	235	172	63	DUE TO SYSTEM CONDITION
		80	96				
8	PARALI-6	1	24	200	166	34	DUE TO SYSTEM CONDITION
		80	96				
9	PARALI-7	1	24	200	166	34	DUE TO SYSTEM CONDITION
		80	96				
10	REL G	1	24	477	336	141	DUE TO SYSTEM CONDITION
		87	96	238	167	71	
11	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	KHAPERKhedA-U5	1	24	428	335	93	DUE TO SYSTEM CONDITION
		87	96				
13	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	INDIABULL TO MSDDL	X	X	X	X	X	UNIT SHUT DOWN
15	CHANDRAPUR	1	24	1350	1198	152	DUE TO SYSTEM CONDITION
		87	96				
16	KHAPER KHEDA U 1 TO 4	1	24	477	431	46	DUE TO SYSTEM CONDITION
		87	96				
17	JSW U-1	1	22	275	200	75	DUE TO SYSTEM CONDITION
		88	96				
19	ADANI U-1	1	22	611	432	179	DUE TO SYSTEM CONDITION
		88	96				
20	PARAS -U3	1	20	182	164	18	DUE TO SYSTEM CONDITION
		88	96	210	164	46	
21	PARAS U4	1	20	182	168	14	DUE TO SYSTEM CONDITION
		88	96	201	168	33	
22	APML U 2	1	20	623	432	191	DUE TO SYSTEM CONDITION
		88	96				

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Nov.-2013.