

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

11-Jan-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	37	483	145	338	AS Per MOD
		38	44	483	320	163	
		51	76	483	360	123	
		77	83	483	210	273	
		84	96	483	145	338	
2	NASIK	1	28	344	310	34	AS Per MOD
		85	96	344	310	34	
3	TPC U-5	1	28	473	260	213	AS Per MOD
		85	90	473	380	93	
		91	96	473	260	213	
4	APML(TIRODA) - MSEDCL	1	23	475	375	100	DC REVISED BY LM CELL
		85	96	475			
5	JSW U2&4 TO MSEDCL	1	4	300	233	67	DC REVISED BY LM CELL
		5	22	300	233	67	AS Per MOD
		85	96	300	210	90	DC REVISED BY LM CELL
6	TPC U-8	X	X	X	X	X	UNIT UNDER OUTAGE
7	BHUSAWAL-3	5	21	161	155	6	AS Per MOD
8	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARLI 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL G	5	21	479	336	143	AS Per MOD
11	BHUSAWAL-4	9	20	420	322	98	AS Per MOD
12	K'KHEDA U-1,2,3,4	9	20	670	620	50	AS Per MOD
13	PARALI-6	13	19	230	164	66	AS Per MOD
14	CHANDRAPUR	17	19	1719	1705	14	AS Per MOD
15	JSW U-1	17	19	275	193	82	DUE TO SYSTEM CONDITION
14	PARAS-4	17	19	230	164	66	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2012.