

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 11-Dec-16 |
|--|------------------------|-------------------------------|----|------------------------------------|-------------------------------|--|--|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUTDOWN |
| 2 | NASIK | 1 | 68 | 182 | 141 | 41 | UNIT-4,5 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| | | 69 | 73 | X | X | X | UNIT-4,5, UNIT-3 TRIPPED AT 16:50HR |
| | | 74 | 96 | 182 | 141 | 41 | UNIT-4 SYN. AT 18:20HRS, UNIT-3,5 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| 3 | REL DAHANU U 1&2 | 1 | 96 | 467 | 336 | 131 | AS PER SYSTEM CONDITION |
| 4 | BHUSWAL U-2,3 | X | X | X | X | X | UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE |
| 5 | RATTANINDIA U1 TO U5 | X | X | X | X | X | UNIT-1,2,3,4,5 W/DNFOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION |
| 6 | TPC U8 | X | X | X | X | X | UNIT SHUTDOWN |
| 7 | TPC U5 | 1 | 40 | X | X | X | RUNNING BELOW TECH MIN |
| | | 41 | 64 | 443 | 292 | 151 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 443 | 292 | 151 | AS PER SYSTEM CONDITION |
| 8 | PARLEY U-8 | X | X | X | X | X | UNIT SHUTDOWN |
| 9 | KORADI U-5 TO U-7 | 1 | 61 | X | X | X | UNIT-6 SHUT DOWN UNI-5 SHUT DOWN UNIT-7 D.C BELOW TECH MIN |
| | | 75 | 96 | X | X | X | UNIT-6 SHUT DOWN UNI-5 SHUT DOWN UNIT-7 D.C BELOW TECH MIN |
| 10 | VIPL U1&2 | 1 | 61 | 546 | 382 | 164 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 546 | 382 | 164 | AS PER SYSTEM CONDITION |
| 11 | PARLEY U-6 AND U-7 | 1 | 31 | 430 | 332 | 98 | AS PER SYSTEM CONDITION |
| | | 49 | 61 | 220 | 166 | 54 | UNIT-7 TRIPPED AT 13:17HRS AND SYN. 16:46HRSAS PER SYSTEM CONDITION |
| | | 75 | 96 | 430 | 332 | 98 | AS PER SYSTEM CONDITION |
| 12 | KHAPERKHEDA U1 TO U4 | 1 | 31 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| | | 49 | 61 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| 13 | BHUSWAL U-4,5 | 1 | 29 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| 14 | PARAS U-3 AND U-4 | 1 | 29 | 230 | 168 | 62 | UNIT-3 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| | | 75 | 96 | 230 | 168 | 62 | UNIT-3 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| 15 | KHAPERKHEDA U-5 | 1 | 29 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 75 | 96 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| 16 | ADANI U1 | X | X | X | X | X | UNIT-1 SHUT DOWN |
| 17 | ADANI U4 | 1 | 29 | X | X | X | D.C TECH MIN |
| | | 81 | 96 | X | X | X | D.C TECH MIN |
| 18 | ADANI U5 | 1 | 29 | X | X | X | D.C TECH MIN |
| | | 81 | 96 | X | X | X | D.C TECH MIN |
| 19 | CHANDRAPUR U3 TO U7 | 1 | 9 | 1165 | 954 | 211 | UNIT-6 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| | | 10 | 29 | 1539 | 1282 | 257 | UNIT-6 SYN. 2:03HRS. B/D AS PER SYSTEM CONDITION |
| | | 81 | 96 | 1539 | 1282 | 257 | UNIT-6 SYN. 2:03HRS. B/D AS PER SYSTEM CONDITION |
| 20 | KORADIU8 AND 9 | 1 | 29 | X | X | X | D.C TECH MIN |
| | | 81 | 96 | 946 | 864 | 82 | AS PER SYSTEM CONDITION |
| 21 | CHANDRAPUR U8 AND U-9 | 1 | 29 | 862 | 657 | 205 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 839 | 657 | 182 | AS PER SYSTEM CONDITION |
| 22 | ADANI UNIT-2 | 1 | 24 | 600 | 432 | 168 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 500 | 432 | 68 | AS PER SYSTEM CONDITION |
| 23 | ADANI U-3 | 1 | 24 | 600 | 432 | 168 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 500 | 432 | 68 | AS PER SYSTEM CONDITION |
| 24 | JSW U-1 | X | X | X | X | X | UNIT SHUTDOWN |

X

X

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD RATES RIVSION R1EFFECTIVE FROM 30TH NOV. 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.