

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	25	204	187	17	AS PER SYSTEM CONDITION
		43	96	204	187	17	AS PER SYSTEM CONDITION
2	JSW TO REL (PXIL)	1	25	125	87.5	37.5	AS PER SYSTEM CONDITION
		43	96	125	87.5	37.5	AS PER SYSTEM CONDITION
3	JSW TO REL (AEML)	1	25	280	196	84	AS PER SYSTEM CONDITION
		43	96	280	196	84	AS PER SYSTEM CONDITION
4	DTPS REL U-1 AND U-2	1	25	456	336	120	AS PER SYSTEM CONDITION
		43	55	456	414	42	AS PER SYSTEM CONDITION
		55	79	X	X	X	#
		80	96	456	336	120	AS PER SYSTEM CONDITION
5	PARALI U-6 AND U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 ZERO SCHEDULE BY LMCELL
6	TPC U-5	1	24	473	292	181	AS PER SYSTEM CONDITION
		80	96	473	292	181	AS PER SYSTEM CONDITION
7	BHUSWAL U-3	X	X	X	X	X	UNIT-3 ZERO SCHEDULE BY LMCELL
8	PARALI U-8	X	X	X	X	X	UNIT-8 ZERO SCHEDULE BY LMCELL
9	NASHIK U-3,4,5	1	24	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
		81	96	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
10	RATTANINDIA U-1 TO U-5	X	X	X	X	X	U-1 TO U-5 ZERO SCHEDULE BY LM CELL
11	VIPL U-1 AND U-2	X	X	X	X	X	UNIT 1 AND UNIT-2 SHUT DOWN
12	BHUSWAL U-4 AND U-5	1	24	940	644	296	AS PER SYSTEM CONDITION
		81	96	926	644	282	AS PER SYSTEM CONDITION
13	KHAPERKhedA U-1 TO U-4	1	24				AS PER SYSTEM CONDITION
		81	96				AS PER SYSTEM CONDITION
14	JSW U-1	1	23	290	200	90	AS PER SYSTEM CONDITION
		81	96	290	200	90	AS PER SYSTEM CONDITION
15	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	23	397	92	305	AS PER SYSTEM CONDITION
		81	96	397	92	305	AS PER SYSTEM CONDITION
16	KHAPERKhedA U-5	1	23	421	335	86	AS PER SYSTEM CONDITION
		82	96	465	335	130	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	1	23	1154	940	214	AS PER SYSTEM CONDITION
		82	96	1154	940	214	AS PER SYSTEM CONDITION
18	KORADI U-8, U9,U-10	1	23	1515	1296	219	AS PER SYSTEM CONDITION
		87	96	1431	1296	135	AS PER SYSTEM CONDITION
19	KORADI U-6 AND U-7	1	22	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
		94	96	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
20	CHANDRAPUR U-8 AND U-9	1	22	940	656	284	AS PER SYSTEM CONDITION
		94	96	921	656	265	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	22	460	432	28	AS PER SYSTEM CONDITION
		94	96	460	432	28	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	22	460	432	28	AS PER SYSTEM CONDITION
		94	96	460	432	28	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	22	227	X	X	TECH MIN
		94	96	227	X	X	TECH MIN
24	PARAS U-3 AND U-4	1	22	X	X	X	UNIT SHUT DOWN
		95	96	X	X	X	UNIT SHUT DOWN
25	ADANI U-2	1	21	623	432	191	AS PER SYSTEM CONDITION
		95	96	623	590	33	AS PER SYSTEM CONDITION
26	ADANI U-3	1	21	623	432	191	AS PER SYSTEM CONDITION
		95	96	623	600	23	AS PER SYSTEM CONDITION

Note :
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 1:12TH FEB- 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.