

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							12-Mar-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) /B/		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASHIK	1	96	364	284	80	UNIT-5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITIN
3	TPC U-8	1	24	468	336	132	AS PER SYSTEM CONDITION
		62	96	468	336	132	AS PER SYSTEM CONDITION
4	TPCU5	1	22	235	187	48	AS PER SYSTEM CONDITION
		62	96	215	187	28	AS PER SYSTEM CONDITION
5	DTPS REL U-1AND U-2	1	22	473	292	181	AS PER SYSTEM CONDITION
		62	96	430	292	138	AS PER SYSTEM CONDITION
6	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	UNIT-1,2,3,4,5 W/DN FOR ZERO SCHEDULE BY MSEDCL
7	BHUSWAL U- 2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULEBY MSEDCL
8	KORADI U-5 TO U-7	X	X	X	X	X	UNIT-6 SHUT DOWN, UNI-5 SHUT DOWN ,UNIT-7 W/DN FOR ZERO SCHEDULE BY MSEDCL AT 14:18HRS. ON 15/02/2017
9	KHAPERKHEDA U1 TO U4	1	21	170	143	27	UNIT-1, UNIT-3 UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
		68	96	175	143	32	UNIT-1, UNIT-3 UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
10	BHUSWAL U-4AND U-5	1	21	950	644	306	AS PER SYSTEM CONDITION
		68	96	950	644	306	AS PER SYSTEM CONDITION
11	PARLYU-6 AND U-7	1	19	458	332	126	AS PER SYSTEM CONDITION
		68	96	458	332	126	AS PER SYSTEM CONDITION
12	KHAPERKHEDA U-5	1	19	475	335	140	B/D AS PER SYSTEM CONDITION
		68	96	456	335	121	B/D AS PER SYSTEM CONDITION
13	PARLY U-8	X	X	X	X	X	UNIT SHUT DOWN
14	PARAS U3 AND U-4	1	19	230	168	62	AS PER SYSTEM CONDITION
		68	96	230	168	62	AS PER SYSTEM CONDITION
15	VIPL U1 AND U2	1	18	273	191	82	UNIT-1SHUT DOWN , B/D AS PER SYSTEM CONDITION
		73	96	273	191	82	UNIT-1SHUT DOWN , B/D AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	74	96	954	808	146	UNIT-10 SHUT DOWN B/D AS PER SYSTEM CONDITION
17	ADANI 440 PPA	74	96	440	0	440	AS PER SYSTEM CONDITION
18	ADANI U-1(1200MW &125MW PPA)	85	96	432	X	X	D.C TECH MIN AS PER SYSTEM CONDITION
19	ADANI U-4(1200MW &125MW PPA)	85	96	432	X	X	D.C TECH MIN AS PER SYSTEM CONDITION
20	ADANI U-5(1200MW &125MW PPA)	85	96	432	X	X	D.C TECH MIN AS PER SYSTEM CONDITION
21	CHANDRAPUR U3 TO U7	85	96	795	626	169	UNIT-6 , UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
22	CHANDRAPUR U8 AND U9	85	96	474	329	145	UNIT-9 SHUT DOWN, B/D AS PER SYSTEM CONDITION
23	ADANI UNIT-2	86	90	623	460	163	AS PER SYSTEM CONDITION
24	ADANI U-3	86	90	623	450	173	AS PER SYSTEM CONDITION
25	JSW U-1	X	X	X	X	X	NO BACK DOWN

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES EFFECTIVE FROM 12TH MARCH 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.