

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2,3,4 TO AEML	1	23	300	210	90	AS PER SYSTEM CONDITION
		50	58	300	210	90	AS PER SYSTEM CONDITION
2	DTPS U-1 AND U-2	1	23	456	336	120	AS PER SYSTEM CONDITION
		51	58	456	336	120	AS PER SYSTEM CONDITION
3	TPC U-8	1	23	225	187	38	AS PER SYSTEM CONDITION
		51	58	225	187	38	AS PER SYSTEM CONDITION
4	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
5	VIPL U-1 AND U-2	X	X	X	X	X	UNIT-1 AND UNIT-2 SHUT DOWN
6	TPC U-5	1	23	460	292	168	AS PER SYSTEM CONDITION
7	KORADI U-6 AND U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT SHUT DOWN
9	NASHIK U-3,4,5	1	23	X	X	X	DC TECH MIN/U-3,5 OUT
		53	58	X	X	X	DC TECH MIN/U-3,5 OUT
10	PARALI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
11	RATTANINDIA U-1 TO U-5	X	X	X	X	X	U-1, U-2,U-3,U-4 & U-5 UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 AND U-5	1	22	780	644	136	AS PER SYSTEM CONDITION
		53	56	780	644	136	AS PER SYSTEM CONDITION
13	CHANDRAPUR U-3 TO U-7	1	22	X	X	X	DC TECH MIN/U-7 OUT
		53	56	X	X	X	DC TECH MIN/U-7 OUT
14	KORADI U-8 TO U-10	1	22	X	X	X	DC TECH MIN/ U-9 OUT
		53	56	X	X	X	DC TECH MIN/ U-9 OUT
15	PARAS U-3 AND U-4	1	22	458	332	126	AS PER SYSTEM CONDITION
16	CHANDRAPUR U-8 AND U-9	1	19	601	572	29	AS PER SYSTEM CONDITION
17	ADANI TIRODA U-1,4,5 (PPA440 MW)	4	19	440	0	440	AS PER SYSTEM CONDITION
18	ADANI TIRODA U-1,4,5 (PPA1200MW,125 MW)	6	19	1405	1296	109	AS PER SYSTEM CONDITION
19	JSW U-1	7	19	285	200	85	AS PER SYSTEM CONDITION
20	KHAPERKHEDA U-1 TO U-4	7	19	X	X	X	DC TECH MIN
21	KHAPERKHEDA U-5	7	19	380	335	45	AS PER SYSTEM CONDITION
22	ADANI U-2 & U-3	X	X	X	X	X	NO BACK DOWN

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD RATES REVISED FROM 15:00HRS OF 16TH APRIL2019 AS PER OLD PROCEDURE Stayed Due to Hon'ble APPELLATE TRIBUNAL order in IA No. 593 of 2019 in DFR No.1762 of 2019
- # Indicates that back down withdrawn due to Line loading/system constraints.
- REVISED MOD RATES EFFECTIVE FROM 00:00HRS 12TH AUG 2019