

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) /B)		
1	TPC U-8	1	25	204	187	17	AS PER SYSTEM CONDITION
		53	60	204	187	17	AS PER SYSTEM CONDITION
		66	71	204	187	17	AS PER SYSTEM CONDITION
		80	96	204	187	17	AS PER SYSTEM CONDITION
2	JSW TO AEML	1	25	X	X	X	NO SCHEDULE
		53	59	X	X	X	NO SCHEDULE
		66	71	X	X	X	NO SCHEDULE
		80	96	175	122	53	AS PER SYSTEM CONDITION
3	DTPS REL U-1 AND U-2	1	25	456	336	120	AS PER SYSTEM CONDITION
		53	59	456	336	120	AS PER SYSTEM CONDITION
		66	69	456	336	120	AS PER SYSTEM CONDITION
		80	96	456	336	120	AS PER SYSTEM CONDITION
4	PARALI U-6 AND U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 ZERO SCHEDULE BY LMCELL
5	JSW U-2,3,4 TO AEML (PXIL)	1	25	125	87.5	37.5	AS PER SYSTEM CONDITION
		53	59	125	87.5	37.5	AS PER SYSTEM CONDITION
		66	69	125	87.5	37.5	AS PER SYSTEM CONDITION
		80	96	125	87.5	37.5	AS PER SYSTEM CONDITION
6	TPC U-5	1	25	473	292	181	AS PER SYSTEM CONDITION
		54	59	473	292	181	AS PER SYSTEM CONDITION
		66	69	473	355	118	AS PER SYSTEM CONDITION
		80	96	473	292	181	AS PER SYSTEM CONDITION
7	BHUSWAL U-3	X	X	X	X	X	UNIT-3 ZERO SCHEDULE BY LMCELL
8	PARALI-8	X	X	X	X	X	UNIT-8 ZERO SCHEDULE BY LMCELL
9	NASHIK U-3,4,5	1	25	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
		55	58	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
		67	69	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
		80	96	187	142	45	UNIT-3 AND UNIT-5 ZERO SCHEDULE BY MSEDCL
10	RATTANINDIA U-1 TO U-5	X	X	X	X	X	U-1 TO U-5 ZERO SCHEDULE BY LM CELL
11	VIPL U-1 AND U-2	X	X	X	X	X	UNIT 1 AND UNIT-2 SHUT DOWN
12	BHUSWAL U-4 AND U-5	1	24	940	644	296	AS PER SYSTEM CONDITION
		55	58	940	644	296	AS PER SYSTEM CONDITION
		80	96	926	644	282	AS PER SYSTEM CONDITION
13	KHAPERKhedA U-1 TO U-4	1	24	576	572	4	AS PER SYSTEM CONDITION
		55	58	576	572	4	AS PER SYSTEM CONDITION
		80	96	576	572	4	AS PER SYSTEM CONDITION
14	JSW U-1	1	24	290	200	90	AS PER SYSTEM CONDITION
		90	96	290	200	90	AS PER SYSTEM CONDITION
15	ADANI TIRODA U-1,4,5(PPA 440MW)	1	23	397	92	305	AS PER SYSTEM CONDITION
		90	96	304	182	122	AS PER SYSTEM CONDITION
16	KHAPERKhedA U-5	1	23	428	335	93	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	1	23	1154	940	214	UNIT-5 SHUT DOWN AS PER SYSTEM CONDITION
18	KORADI U-8, U9,U-10	1	23	1455	1296	159	AS PER SYSTEM CONDITION
19	KORADI U-6 AND U-7	1	22	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
20	CHANDRAPUR U-8 AND U-9	1	22	940	644	296	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	22	460	432	28	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	22	460	432	28	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	22	277	X	X	TECH MIN
24	PARAS U-3 AND U-4	1	22	X	X	X	UNIT SHUT DOWN
25	ADANI U-2	1	19	623	432	191	AS PER SYSTEM CONDITION
26	ADANI U-3	1	19	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 1:12TH FEB- 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.