

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|----------------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|---|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | DHARIWAL TO RINFRA (DA) | 70 | 77 | X | X | X | NO SCHEDULE |
| 2 | TPC U-8 | 70 | 77 | 204 | 187 | 17 | AS PER SYSTEM CONDITION |
| 3 | TPC U-5 | 70 | 77 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 4 | JSW TO MSEDCL | 70 | 77 | 240 | 168 | 72 | AS PER SYSTEM CONDITION |
| 5 | SWPCL TO MSEDCL | 70 | 77 | X | X | X | UNIT IS RUNNING ON TECHENICAL MINIMUM LOAD |
| 6 | DTPS REL U-1 AND U-2 | 74 | 77 | 452 | 336 | 116 | AS PER SYSTEM CONDITION |
| 7 | JSW TO BEST | 74 | 77 | 125 | 87.5 | 37.5 | AS PER SYSTEM CONDITION |
| 8 | NASIK U-3,4 AND 5 | 74 | 77 | 355 | 283 | 72 | AS PER SYSTEM CONDITION |
| 9 | PARALI U-6 AND U-7 | 74 | 76 | 458 | 332 | 126 | AS PER SYSTEM CONDITION |
| 10 | BHUSWAL U-3 | 74 | 76 | 178 | 144 | 34 | AS PER SYSTEM CONDITION |
| 11 | PARALI U-8 | 74 | 76 | X | X | X | D.C. BELOW TECH MIN |
| 12 | VIPL U-1 AND U-2 | X | X | X | X | X | NO BACK DOWN UNIT-1 SHUT DOWN |
| 13 | RATTANINDIA U-1 TO U-5 | X | X | X | X | X | NO BACK DOWN UNIT-1 ,2,4 SHUT DOWN |
| 14 | BHUSWAL U-4 AND U-5 | X | X | X | X | X | NO BACK DOWN |
| 15 | PARAS U-3 &U-4 | X | X | X | X | X | NO BACK DOWN |
| 16 | IEPL TO MSEDCL | X | X | X | X | X | UNIT SHUT DOWN |
| 17 | DHARIWAL TO MSEDCL | X | X | X | X | X | NO BACK DOWN |
| 18 | KHAPERKHEDA U-1 TO U-4 | X | X | X | X | X | NO BACK DOWN |
| 19 | ADANI (TIRODA 440MW PPA) U1,4,&5 | X | X | X | X | X | NO BACK DOWN |
| 20 | KHAPERKHEDA U-5 | X | X | X | X | X | NO BACK DOWN |
| 21 | ADANI U-1(1200+125)MW PP | X | X | X | X | X | NO BACK DOWN |
| 22 | ADANI U-4(1200+125)MW PP | X | X | X | X | X | NO BACK DOWN |
| 23 | ADANI U-5(1200+125)MW PP | X | X | X | X | X | UNIT SHUT DOWN |
| 24 | KORADI U-6&U-7 | X | X | X | X | X | UNIT SHUT DOWN |
| 25 | KORADI U-8,9 &U-10 | X | X | X | X | X | NO BACK DOWN |
| 26 | JSW U-1 | X | X | X | X | X | NO BACK DOWN |
| 27 | CHANDRAPUR U-3 TO U-7 | X | X | X | X | X | NO BACK DOWN UNIT-3 ,UNIT-4, UNIT-6 SHUT DOWN |
| 28 | CHANDRAPUR U-8 &U-9 | X | X | X | X | X | NO BACK DOWN |
| 29 | ADANI U-2 | X | X | X | X | X | NO BACK DOWN |
| 30 | ADANI U-3 | X | X | X | X | X | NO BACK DOWN |

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT 12-May-18
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.