

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							13-Jul-16
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	X	X	X	UNIT SHUTDOWN
2	NASIK	1	26	374	283	91	AS PER SYSTEM CONDITION
		43	78	374	283	91	AS PER SYSTEM CONDITION
3	BHUSWAL U 2,3	X	X	X	X	X	MSEDCL W/DN UNIT-3 FOR ZERO SCHEDULE AND UNIT-2SHUT DOWN
4	REL DAHANU U 1&2	1	26	470	336	134	AS PER SYSTEM CONDITION
		43	78	x	x	x	#
5	BHUSWAL U-4 & 5	x	x	X	X	X	UNIT-4 AND UNIT-5 W/DN BY MSEDCLFOR ZERO SCHEDULE
6	TPC U-8	1	26	235	187	48	AS PER SYSTEM CONDITION
		43	78	x	x	x	#
7	TPC U-5	1	26	473	292	181	AS PER SYSTEM CONDITION
		43	78	x	x	x	#
8	RATTAN INDIA U1 TO U5	x	x	X	X	X	MSEDCL W/DN UNIT- 1 TO 5 FOR ZERO SCHEDULE
9	KORADI U-5 TO U-7	x	x	X	X	X	UNIT-6 SHUT DOWN UNIT-5 AND UNIT-7 W/DN BY MSEDCL FOR ZERO SCHEDULE
10	KHAPERKHEDA U1 TO U4	X	X	X	X	X	AS PER SYSTEM CONDITION UNIT-4 W/DN AOH . MSEDCL W/DN UNIT-2 UNIT-3 UNIT-1 FOR ZERO SCHEDULE
11	VIPL U1&2	1	25	546	382	164	AS PER SYSTEM CONDITION
		43	78	546	382	164	AS PER SYSTEM CONDITION
12	ADANI U-1	1	10	466.33	432	34.33	AS PER SYSTEM CONDITION UNIT W/DN FOR ZERO SCHEDULE BY MSEDCL AT 2:29HRS
13	ADANI U-4	1	10	466.33	432	34.33	AS PER SYSTEM CONDITION UNIT W/DN FOR ZERO SCHEDULE BY MSEDCLAT 2:22HRS.
14	ADANI U-5	1	24	605	432	173	AS PER SYSTEM CONDITION
		44	77	605	432	173	AS PER SYSTEM CONDITION
15	PARAS U-3 AND U-4	1	24	460	332	128	AS PER SYSTEM CONDITION
		44	76	460	332	128	AS PER SYSTEM CONDITION
16	CHANDRAPUR U-3 to 7	1	24	1734	1282	452	AS PER SYSTEMCONDITION
		44	48	1296	954	342	AS PER SYSTEM CONDITION UNIT-7TRIPPED
		49	74	1734	1282	452	AS PER SYSTEM CONDITION UNIT-7 SYN.
17	KHAPERKHEDA U-5	1	24	475	335	140	AS PER SYSTEM CONDITION
		46	74	475	335	140	AS PER SYSTEM CONDITION
18	KORADI U-8	1	24	620	432	188	AS PER SYSTEM CONDITION
		54	74	620	432	188	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-8	1	24	x	x	x	D.C BELOW TECH MIN.
		54	74	x	x	x	D.C BELOW TECH MIN.
20	ADANI U-3	1	20	623	432	191	AS PER SYSTEM CONDITION
		46	48	585	555	30	AS PER SYSTEM CONDITION
21	ADANI U-2	1	20	623	432	191	AS PER SYSTEM CONDITION
		46	48	605	570	35	AS PER SYSTEM CONDITION
22	JSW U-1	X	X	X	X	X	NO BACK DOWN

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM 12 TH OF JULY 2016
- # Indicates that back down withdrawn due to Line loading/system constraints.