

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
2	NASIK U-3, U-4 & U-5	X	X	X	X	X	U-3&4 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
3	DTPS U-1 & U-2	1	35	227.5	167	60.5	AS PER SYSTEM CONDITION /U-1 UNDER ZERO SCHEDULE
		42	73	227.5	167	60.5	
		77	96	227.5	167	60.5	
4	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
5	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
6	TPC U-5	1	35	470	292	178	AS PER SYSTEM CONDITION
		42	73	470	292	178	AS PER SYSTEM CONDITION
		77	96	470	292	178	AS PER SYSTEM CONDITION
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	TPC U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	APML U-1, U-4 & U-5 (PPA440 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	APML U-1, U-4 & U-5 (PPA1200MW, 125 MW)	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
13	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
14	KORADI U-8 TO U-10	1	27	860	802	58	AS PER SYSTEM CONDITION/ U-10 UNDER ZERO SCHEDULE
		42	72	860	802	58	
		78	96	860	802	58	
15	BHUSAWAL U-4 & U-5	1	26	902	644	258	AS PER SYSTEM CONDITION
		44	72	902	644	258	AS PER SYSTEM CONDITION
		82	96	902	644	258	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case- IV)	1	26	185	129.5	55.5	AS PER SYSTEM CONDITION
		44	72	185	129.5	55.5	AS PER SYSTEM CONDITION
		82	96	185	129.5	55.5	AS PER SYSTEM CONDITION
17	PARAS U-3 & U-4	1	26	454	332	122	AS PER SYSTEM CONDITION
		46	72	454	332	122	AS PER SYSTEM CONDITION
		82	96	454	332	122	AS PER SYSTEM CONDITION
18	JSW U-1	1	25	286	200	86	AS PER SYSTEM CONDITION
		46	72	286	200	86	AS PER SYSTEM CONDITION
		82	96	286	200	86	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-3 TO U-7	1	22	544	478	66	AS PER SYSTEM CONDITION/ U-3,6&7 OUT
		46	72	544	478	66	AS PER SYSTEM CONDITION/ U-3,6&7 OUT
		82	96	544	478	66	AS PER SYSTEM CONDITION/ U-3,6&7 OUT
20	KHAPERKHEDA U-1 TO U-4	1	22	X	X	X	DC TECH MIN
		46	72	X	X	X	DC TECH MIN
		82	96	X	X	X	DC TECH MIN
21	CHANDRAPUR U-8 & U-9	1	21	856	656	200	AS PER SYSTEM CONDITION
		47	70	856	656	200	AS PER SYSTEM CONDITION
		83	96	856	656	200	AS PER SYSTEM CONDITION
22	KHAPERKHEDA U-5	1	19	432	335	97	AS PER SYSTEM CONDITION
		47	70	432	335	97	AS PER SYSTEM CONDITION
		83	96	432	335	97	AS PER SYSTEM CONDITION
23	SWPGL to BEST	1	18	100	70	30	AS PER SYSTEM CONDITION
		48	70	100	70	30	AS PER SYSTEM CONDITION
		83	96	100	70	30	AS PER SYSTEM CONDITION
24	APML U-2 & U-3	1	17	1234	864	370	AS PER SYSTEM CONDITION
		48	60	1234	864	370	AS PER SYSTEM CONDITION
		66	70	1234	864	370	AS PER SYSTEM CONDITION
		83	96	1234	864	370	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
- 2 Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 4 Revised MOD Rates effective from 00:00 hrs of 13th Aug 2020