

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

14-Jan-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max in MW) [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	21	483	145	338	AS Per MOD
		86	96	483	240	243	
2	JSW U-4 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs & 21:00 to 24:00 : 190 MW (TECHNICAL MINIMUM)
3	ABHIJIT TO MSEDCL (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 52 TO 35 MW (00:00 TO 05:00 HRS) & (21 :00 to 24:00)
4	JSW U-3 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:45 hrs & 20:15 to 24:00: 190 MW (TECHNICAL MINIMUM)
5	TPC U-5	X	X	X	X	X	UNDER OUTAGE
6	TPC U-8	4	21	230	160	70	AS Per MOD
7	JSW U-2 (STOA)	6	20	275	220	55	MSEDCL HAS CURTAILED POWER FROM 275 TO 190 (00:00 TO 05:00 HRS) (TECHNICAL MINIMUM)
8	NASHIK #						

NASHIK SCHEDULE WAS REDUCED AS PER MOD. DUE TO LESS AVAILABILITY DECLARED BY NASHIK IN REV, NO BACKDOWN.

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".