

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|---------------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|--|
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT WITHDRAWN ON ECONOMIC SHUTDOWN |
| 2 | JSW TO MSEDCL | 1 | 20 | 275 | 192.5 | 82.5 | AS PER SYSTEM CONDITION |
| | | 74 | 93 | 275 | 192.5 | 82.5 | AS PER SYSTEM CONDITION |
| 3 | TPC U-5 | 1 | 19 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 84 | 93 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 4 | TPC U-8 | 1 | 19 | 230 | 187 | 43 | AS PER SYSTEM CONDITION |
| | | 84 | 93 | 230 | 187 | 43 | AS PER SYSTEM CONDITION |
| 5 | DTPS REL U1 AND U2 | 1 | 19 | 460 | 336 | 124 | AS PER SYSTEM CONDITION |
| | | 84 | 89 | 460 | 336 | 124 | AS PER SYSTEM CONDITION |
| 6 | NASHIK U-3,4,5 | 1 | 18 | 300 | 283 | 17 | UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION |
| | | 84 | 88 | X | X | X | # UNIT-3 SHUT DOWN ,UNIT-5 TRIPPED AS PER SYSTEM CONDITION |
| 7 | RATTANINDIA U-1 TO U-5 | 1 | 17 | 490 | 344 | 146 | UNIT-4SHUT DOWN, UNIT-3 SHUT DOWN and UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION |
| | | 84 | 88 | 490 | 344 | 146 | UNIT-4SHUT DOWN, UNIT-3 SHUT DOWN and UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION |
| 8 | BHUSAWAL U-3 | X | X | X | X | X | UNIT SHUT DOWN |
| 9 | VIPL U-1 AND U-2 | 1 | 6 | 477 | 382 | 95 | AS PER SYSTEM CONDITION |
| 10 | PARALI U-6 AND U-7 | 1 | 4 | 458 | 332 | 126 | AS PER SYSTEM CONDITION |
| 11 | PARALI U-8 | X | X | X | X | X | NO BACK DOWN |
| 12 | BHUSWAL U-4 AND U-5 | X | X | X | X | X | NO BACK DOWN |
| 13 | PARAS U-3 AND U-4 | X | X | X | X | X | NO BACK DOWN |
| 14 | KHAPERKHEDA U-1 TO U-4 | X | X | X | X | X | UNIT-1 AND UNIT-2 SYN.22:20 AND UNIT-3 TRIPPED 00:27HRS NO BACK DOWN |
| 15 | ADANI (TIRODA 440MW PPA) U1,4&5 | X | X | X | X | X | NO BACK DOWN |
| 16 | ADANI U-1 (1200+125)MW PP | X | X | X | X | X | NO BACK DOWN |
| 17 | ADANI U-4 (1200+125)MW PP | X | X | X | X | X | UNIT SHUT DOWN |
| 18 | ADANI U-5(1200+125)MW PP | X | X | X | X | X | NO BACK DOWN |
| 19 | KORADI U-6 AND U-7 | X | X | X | X | X | UNIT SHUT DOWN |
| 20 | KHAPERKHEDA U-5 | X | X | X | X | X | NO BACK DOWN |
| 21 | KORADI U-8,9 AND U-10 | X | X | X | X | X | NO BACK DOWN |
| 22 | CHANDRAPUR U-3 TO U-7 | X | X | X | X | X | NO BACK DOWN UNIT-3,4,6,7 SHUT DOWN |
| 23 | JSW U-1 | X | X | X | X | X | SHUT DOWN |
| 24 | CHANDRAPUR U-8AND U-9 | X | X | X | X | X | NO BACK DOWN |
| 25 | ADANI U-2 | X | X | X | X | X | UNIT SHUT DOWN |
| 26 | ADANI U-3 | X | X | X | X | X | NO BACK DOWN |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT.12TH MARCH 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.