

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 14-May-17 |
|--|------------------------------|--|----|---------------------------------------|-------------------------------------|--|---|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum (Max) in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUTDOWN |
| 2 | NASHIK | 1 | 96 | 546 | 425 | 121 | AS PER SYSTEM CONDITION |
| 3 | REL DAHANU U1 AND U2 | 1 | 96 | 467 | 336 | 131 | AS PER SYSTEM CONDITION |
| 4 | TPCU-8 | 1 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 5 | TPC U-5 | 1 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 6 | JSW PTC DA1 | X | X | X | X | X | BID VARIABLE SCHEDULE |
| 7 | RATTANINDIA U1,2,3,4,5 | 1 | 96 | 735 | 516 | 219 | U-4 & 5 SHUTDOWN, BD AS PER SYSTEM CONDITION |
| 8 | BHUSWAL U2,3 | 1 | 96 | X | X | X | UNIT-2 SHUT DOWN ,UNIT-3D.C TECH MIN |
| 9 | KORADI U-5 TO U-7 | 1 | 96 | X | X | X | UNIT-7 RUNNING BELOW TECH MIN UNIT-5 AND UNIT-6 SHUT DOWN |
| 10 | DHARIWAL TO MSEB | 1 | 96 | 150 | 140 | 10 | AS PER SYSTEM CONDITION |
| 11 | VIPL U1 AND U2 | 1 | 96 | 546 | 382 | 164 | AS PER SYSTEM CONDITION |
| 12 | PARLEY U-8 | 1 | 5 | X | X | X | UNIT SHUT DOWN |
| | | 6 | 96 | 200 | 166 | 34 | AS PER SYSTEM CONDITION UNIT SYN. AT 1:04HRS |
| 13 | BHUSWAL U-4 AND U-5 | 1 | 96 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| 14 | PARLEY U-6,7 | 1 | 96 | 458 | 332 | 126 | AS PER SYSTEM CONDITION |
| 15 | KHAPERKHEDA U1 TO U4 | 1 | 46 | 711 | 572 | 139 | AS PER SYSTEM CONDITION |
| | | 53 | 96 | 711 | 572 | 139 | AS PER SYSTEM CONDITION |
| 16 | KHAPERKHEDA U-5 | 1 | 46 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 53 | 96 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| 17 | KORADI U8 ,U9,10 | 1 | 46 | X | X | X | UNIT D.C BELOW TECH MIN |
| | | 53 | 96 | X | X | X | UNIT D.C BELOW TECH MIN |
| 18 | PARAS U-3 ANDU-4 | 1 | 45 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| | | 53 | 96 | 460 | 332 | 128 | AS PER SYSTEM CONDITION |
| 19 | ADANI 440 PPA | 1 | 45 | 363.431 | X | X | D.C BELOW TECH MIN |
| | | 55 | 95 | 363.431 | X | X | D.C BELOW TECH MIN |
| 20 | ADANI U-1(1200MW &125MW PPA) | 1 | 45 | 266.558 | X | X | D.C BELOW TECH MIN |
| | | 55 | 95 | 266.558 | X | X | D.C BELOW TECH MIN |
| 21 | ADANI U-4(1200MW &125MW PPA) | 1 | 45 | 266.558 | X | X | D.C BELOW TECH MIN |
| | | 55 | 95 | 266.558 | X | X | D.C BELOW TECH MIN |
| 22 | ADANI U-4(1200MW &125MW PPA) | 1 | 45 | 266.558 | X | X | D.C BELOW TECH MIN |
| | | 55 | 95 | 266.558 | X | X | D.C BELOW TECH MIN |
| 23 | CHANDRAPUR U3 TO U7 | 1 | 9 | 1225 | 954 | 271 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| | | 15 | 20 | 1225 | 954 | 271 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| | | 28 | 45 | 1225 | 954 | 271 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| | | 55 | 64 | 1225 | 954 | 271 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| | | 70 | 95 | 1225 | 954 | 271 | AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN |
| 24 | CHANDRAPUR U8 AND U9 | 1 | 9 | 948 | 658 | 290 | AS PER SYSTEM CONDITION |
| | | 15 | 20 | 948 | 658 | 290 | AS PER SYSTEM CONDITION |
| | | 55 | 64 | 948 | 658 | 290 | AS PER SYSTEM CONDITION |
| | | 70 | 95 | 948 | 658 | 290 | AS PER SYSTEM CONDITION |
| 25 | ADANI UNIT-2 | 1 | 9 | X | X | X | D.C BELOW TECH MIN |
| | | 34 | 43 | X | X | X | D.C BELOW TECH MIN |
| | | 71 | 94 | X | X | X | D.C BELOW TECH MIN |
| 26 | ADANI U-3 | 1 | 9 | X | X | X | D.C BELOW TECH MIN |
| | | 34 | 43 | X | X | X | D.C BELOW TECH MIN |
| | | 71 | 94 | X | X | X | D.C BELOW TECH MIN |
| 27 | JSW U-1 | 34 | 43 | 230 | 200 | 30 | AS PER SYSTEM CONDITION |
| | | 71 | 87 | 230 | 200 | 30 | AS PER SYSTEM CONDITION |
| | | 89 | 94 | 230 | 200 | 30 | AS PER SYSTEM CONDITION |

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D RATES EFFECTIVE FROM 12TH AF May-17
- # Indicates that back down withdrawn due to Line loading/system constraints.