

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: <u>14-Jun-14</u>							
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	BELOW TECH MIN
2	NASIK	70	80	536	425	111	AS PER MOD
3	JSW TO RINFRA DA	71	80	52	36.4	16	DUE TO SYSTEM CONDITION
4	JSW TO RINFRA (100 MW)	71	80	100	70	30	DUE TO SYSTEM CONDITION
5	KORADI	x	x	x	x	x	BELOW TECH MIN
6	BHUSAWAL-2,3	x	x	x	x	x	BELOW TECH MIN
7	JSW TO MSEDCL (100 MW)	71	80	100	70	30	AS PER MOD
8	VIPL TO RINFRA U-1	x	x	x	x	x	DECL TECH MIN
9	VIPL TO RINFRA U-2	71	80	230	190	40	AS PER MOD
10	PARALI-3,4,5	71	80	141	138	3	AS PER MOD
11	TPC U-8	x	x	x	x	x	UNIT SHUT DOWN
12	TPC U-5	71	80	x	x	x	#
13	JSW TO MSEDCL (285 MW)	71	80	285	199.5	86	AS PER MOD
14	BHUSAWAL U4	71	80	329	322	7	AS PER MOD
15	BHUSAWAL U-5	x	x	x	x	x	BELOW TECH MIN
16	REL GEN	71	80	x	x	x	#
17	KHAPER KHEDA U 5	71	80	x	x	x	DECL BELOW TECH MIN
18	PARLY U-6	71	80	229	166	63	DUE TO SYSTEM CONDITION
19	CHANDRAPUR	71	80	1287	1186	101	DUE TO SYSTEM CONDITION
20	PARLY U-7	71	80	210	166	44	DUE TO SYSTEM CONDITION
21	INDIA BULL U1	71	80	205	172	33	DUE TO SYSTEM CONDITION
22	KHAPER KHEDA U 1 TO 4	71	80	x	x	x	DC REVISED BELOW TECH MIN
23	INDIA BULL U2	71	80	200	172	28	DUE TO SYSTEM CONDITION
24	PARAS -U3	71	80	182	164	18	DUE TO SYSTEM CONDITION
25	ADANI U-1 AND U-4	71	80	1200	952	248	DUE TO SYSTEM CONDITION
26	PARAS U4	77	79	230	168	62	DUE TO SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-June-2014.
- 3 # BACKED DOWN AS PER MOD. WITHDRWAN DUE TO SYSTEM CONDITION.