

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:14/11/2018

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Mlin) (B)		
1	Dhariwal to BEST	X	X	X	X	X	No Schedule
2	SWPL TO MSEDCL(GMR)	1	96	68	81	17	As per System Condition
3	JSW U-2,3&4 TO MSEDCL (155.5MW)	1	96	155.5	108.85	46.65	As per System Condition
4	TPC U-8	1	96	204	187	17	As per System Condition
5	SWPCL U-1,2 AND 4 TO MSEDCL	1	28	83	63	20	As per System Condition
		35	96	83	63	20	As per System Condition
6	SWPCL U-1,2 AND 4 TO MSEDCL	1	27	68	51	17	As per System Condition
		35	96	68	51	17	As per System Condition
7	JSW U-2,3&4 TO MSEDCL (247MW)	1	26	247.2	173	74.2	As per System Condition
		47	96	247.2	173	74.2	As per System Condition
8	TPC U-5	1	26	473	292	181	As per System Condition
		47	96	473	292	181	As per System Condition
9	VIPL U-1 & 2	1	26	286	191	95	unit-1 shut down AS PER SYSTEM CONDITION
		47	96	286	191	95	unit-1 shut down AS PER SYSTEM CONDITION
10	DTPS REL U-1 & 2	1	24	456	336	120	As per System Condition
		49	96	456	336	120	As per System Condition
11	NASIK U-3,4 & 5	X	X	X	X	X	DC LESS THAN TECH MIN.
12	BHUSAWAL U-3	X	X	X	X	X	Unit Shut Down, Coal Swapping IEPL
13	RATTANINDIA U-1 TO 5 (PPA-1200 MW)	1	20	245	172	73	As per System Condition, U-1,U-3, U-4, S Shut Down
		71	74	245	172	73	As per System Condition, U-1,U-3, U-4, S Shut Down
		81	96	245	172	73	As per System Condition, U-1,U-3, U-4, S Shut Down
14	PARALI U-6 & 7	1	20	229	166	63	As per System Condition, U-7Shut Down
		71	74	229	166	63	As per System Condition, U-7Shut Down
		81	96	229	166	63	As per System Condition, U-7Shut Down
15	PARALI U-8	1	20	229	166	63	As per System Condition
		71	74	229	166	63	As per System Condition
		81	96	229	166	63	As per System Condition
16	BHUSAWAL U-4 & 5	1	20	658	644	14	As per System Condition
		81	96	658	644	14	As per System Condition
17	KORADI U-6 & 7	X	X	X	X	X	U-6 & U-7Shut Down
18	IDEAL ENERGY PROJECTS LTD. TO MSEDCL	X	X	X	X	X	Unit Shut Down
19	DHARIWAL TO MSEDCL (Case-4)	1	20	X	X	X	DC Less than Tech Min
		82	96	190	175	15	As per System Condition
20	KHAPERKHEDA U- 1 TO 4	61	66	527	431	96	As per System Condition, U-1 Shut Down
		93	96	518	431	87	As per System Condition, U-1 Shut Down
21	JSW-Ratnagiri U-1	1	20	274	200	74	As per System Condition
		83	96	274	200	74	As per System Condition
22	KORADI U-8 ,9 &10	X	X	X	X	X	DC Less than Tech Min
23	KHAPERKHEDA U-5	1	20	475	335	140	As per System Condition
		83	96	475	335	140	As per System Condition
24	PARAS U-3 & 4	1	17	230	168	62	As per System Condition, U-3 Shut Down
		83	96	230	168	62	As per System Condition, U-3 Shut Down
25	ADANI (TIRODA 440 MW PPA) U 1,4 & 5	1	17	440	0	440	As per System Condition
		83	96	440	0	440	As per System Condition
26	CHANDRAPUR U-3 TO 7	1	17	1209	988	221	As per System Condition
		85	96	1126	988	138	As per System Condition
27	ADANI ,TIRODA U-1, 4 & 5 (PPA-1200 MW and 125 MW)	1	16	1326	1296	30	As per System Condition
		85	96	1326	1296	30	As per System Condition
28	CHANDRAPUR U-8 & 9	1	16	826	696	170	As per System Condition
		89	96	789	696	133	As per System Condition
29	ADANI (TIRODA 1320 MW) U 2 & 3	1	6	1246	864	382	As per System Condition
		92	96	1246	1146	100	As per System Condition

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM DT. 12TH SEPT-2018
- # Indicates that back down withdrawn due to Line loading/system constraints.