

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

15-Jan-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max in MW) [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	22	483	145	338	AS Per MOD
		85	96	483	145	338	
2	JSW U-4 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs & 21:00 to 24:00 : 190 MW (TECHNICAL MINIMUM)
3	ABHIJIT TO MSEDCL (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 52 TO 35 MW (00:00 TO 05:00 HRS) & (21 :00 to 24:00)
4	JSW U-3 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:45 hrs & 20:15 to 24:00: 190 MW (TECHNICAL MINIMUM)
5	TPC U-5	X	X	X	X	X	UNDER OUTAGE
6	TPC U-8	1	20	230	160	70	AS Per MOD
7	JSW U-2 (STOA)	1	20	275	220	55	MSEDCL HAS CURTAILED POWER FROM 275 TO 190 (00:00 TO 05:00 HRS) (TECHNICAL MINIMUM)
8	NASHIK	1	20	384	320	64	AS Per MOD
8	REL_G	1	20	480	336	144	AS Per MOD
9	BSL	5	20	331	326	5	AS Per MOD
10	PARLI 4	5	20	610	605	5	AS Per MOD
11	PARLI 5	X	X	X	X	X	Declared Capacity (135 MW) less than TECHNICAL MINIMUM (150 MW)
12	K'KHEDA	5	20	567	480	87	AS Per MOD
13	PARLI_ 6	X	X	X	X	X	Declared Capacity (160 MW) as TECHNICAL MINIMUM (160 MW)
14	JSW U1	6	20	275	190	85	AS Per MOD
15	PARLI_ 7	X	X	X	X	X	Declared Capacity (160 MW) as TECHNICAL MINIMUM (160 MW)
16	KORADI	8	20	180	160	20	AS Per MOD
17	CHANDRAPUR #						

DUE TO SYSTEM CONDITION, CHANDRAPUR BACKINGDOWN WAS WITHDRAWN

Note :

1

Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".