SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	то	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASHIK U-3, U-4 & U-5	х	х	х	х	х	U-3&4 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
2	BHUSAWAL U-3	Х	Х	Х	Х	Х	UNIT UNDER ZERO SCHEDULE
3	KORADI U-6 & U-7	Х	Х	Х	Х	Х	UNITS UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	Х	Х	Х	Х	Х	UNITS SHUT DOWN
5	DTPS U-1 & U-2	40	77	455	336	119	AS PER SYSTEM CONDITION
6	TPC U-8	Х	Х	Х	Х	Х	UNIT UNDER ZERO SCHEDULE
7	TPC U-5	40	77	470	292	178	AS PER SYSTEM CONDITION
8	RATTANINDIA U-1 TO U-5	Х	Х	Х	Х	Х	UNITS UNDER ZERO SCHEDULE
9	PARALI U-6 & U-7	Х	Х	Х	Х	Х	UNITS UNDER ZERO SCHEDULE
10	BHUSAWAL U-4 & U-5	Х	Х	Х	X	X	UNITS UNDER ZERO SCHEDULE
11	KORADI U-8 TO U-10	Х	Х	Х	X	X	UNITS UNDER ZERO SCHEDULE
12	PARALI U-8	Х	Х	Х	X	X	UNIT UNDER ZERO SCHEDULE
13	CHANDRAPUR U-3 TO U-7	X	Х	Х	X	Х	UNITS UNDER ZERO SCHEDULE
14	KHAPERKHEDA U-1 TO U-4	43	74	666	572	94	AS PER SYSTEM CONDITION
15	JSW TO AEML_DA	47	74	225	157.5	67.5	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-5	47	74	423	335	88	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA440 MW)	53	71	430	330	100	AS PER SYSTEM CONDITION
18	CHANDRAPUR U-8 & U-9	Х	Х	Х	Х	Х	NO BACK DOWN
19	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	х	х	х	х	х	NO BACK DOWN
20	PARAS U-3 & U-4	Х	Х	Х	Х	Х	NO BACK DOWN
21	DHARIWAL TO MSEDCL(CASE IV)	х	х	х	х	х	NO BACK DOWN
22	JSW U-1	Х	Х	Х	Х	Х	NO BACK DOWN
23	SWPGL to BEST	Х	Х	Х	Х	Х	NO BACK DOWN
24	APML U-2 & U-3	Х	Х	Х	X	X	NO BACK DOWN

Note:

- 1
- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.

 Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

 # Indicates that back down withdrawn due to Line loading/system constraints.

 * Indicates that back down implemented due to Line loading/system constraints.

 Revised MOD Rates effective from 00:00 hrs of 12th Apr 2020
- 2
- 3 4