

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							15-Jun-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	JSW TO RINFRA	1	77	X	X	X	B/D AS PER SYSTEM CONDITION, VARIABLE SCHEDULE, BLK. NO 79 TO 96
3	NASHIK	1	24	384	283	101	B/D AS PER SYSTEM CONDITION, UNIT-3 CONVERTED TO ZEROSCHEDULE BY MSEDCL FROMMM 60HRS OF 1/06/2017
		29	77	384	283	101	B/D AS PER SYSTEM CONDITION, UNIT-3 CONVERTED TO ZEROSCHEDULE BY MSEDCL FROMMM 60HRS OF 1/06/2017
4	REL DAHANU U1 AND U2	1	23	464	336	128	AS PER SYSTEM CONDITION
		31	77	464	336	128	AS PER SYSTEM CONDITION
5	TPC U-8	1	23	235	187	48	AS PER SYSTEM CONDITION
		31	77	235	187	48	AS PER SYSTEM CONDITION
6	TPC U-5	3	23	473	292	181	AS PER SYSTEM CONDITION
		35	77	473	292	181	AS PER SYSTEM CONDITION
7	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	unit-2 , UNIT-5 WIDN , UNIT-4 WIDN RS FOR ZERO SCHEDULE BY MSEDCL. UNIT-1 AND UNIT-3 SHUT DOWN
8	BHUSWAL U2,3	X	X	X	X	X	UNIT-2 SHUT DOWN, UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL
9	PARLEY U-6 AND U-7	X	X	X	X	X	UNIT-7 WIDN and UNIT-6 FOR ZERO SCHEDULE BY MSEDCL AS PER SYSTEM CONDITION
10	PARLEY U-8	10	23	180	166	14	AS PER SYSTEM CONDITION
		37	46	180	166	14	AS PER SYSTEM CONDITION
		47	72	X	X	X	UNIT- TRIPPED AT 11:29HRS AND SYN 17:59HRS
		72	77	X	X	X	D.C. BELOW TECH MIN.
11	BHUSWAL U-4 AND U-5	10	22	470	322	148	UNIT -5 SHUT DOWN AS PER SYSTEM CONDITION
		38	71	470	322	148	UNIT -5 SHUT DOWN AS PER SYSTEM CONDITION
12	KHAPERKHEDA U1 TO U4	11	22	X	X	X	D.C BELOW TECH MINAS PER SYSTEM CONDITION UNIT-2 SHUT DOWN UNIT-3 TRIPPED
		43	71	X	X	X	D.C BELOW TECH MINAS PER SYSTEM CONDITION
13	KORADI-5,6,7	11	22	X	X	X	UNIT-5 , UNIT-6 SHUT DOWN UNIT -7 RUNNING BELOW TECH MIN
		43	71	X	X	X	UNIT-5 , UNIT-6 SHUT DOWN UNIT -7 RUNNING BELOW TECH MIN
14	VIPL U1,2	11	22	286	191	95	AS PER SYSTEM CONDITION
		43	71	286	191	95	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-5	11	22	376	322	54	AS PER SYSTEM CONDITION
		43	71	376	322	54	AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	13	22	X	X	X	D.C. BELOW TECH MIN.
		43	71	X	X	X	D.C. BELOW TECH MIN.
17	PARAS U-3 ANDU-4	13	22	460	332	128	AS PER SYSTEM CONDITION
		43	71	460	332	128	AS PER SYSTEM CONDITION
18	ADANI 440 PPA	17	22	427	110	317	AS PER SYSTEM CONDITION
		51	70	440	0	440	AS PER SYSTEM CONDITION
19	CHANDRAPUR U3 TO U7	17	22	1461	1282	179	AS PER SYSTEM CONDITION
		62	70	1461	1282	179	AS PER SYSTEM CONDITION
20	ADANI U-1(1200MW &125MW PPA)	62	70	X	X	X	D.C . BELOW TECH MIN. UNIT WIDN AT17:27
21	ADANI U-4(1200MW &125MW PPA)	62	70	468	432	36	AS PER SYSTEM CONDITION
22	ADANI U-5(1200MW &125MW PPA)	X	X	468	432	36	AS PER SYSTEM CONDITION
23	CHANDRAPUR U8 AND U9	X	X	758	658	100	AS PER SYSTEM CONDITION
24	ADANI UNIT-2	65	69	X	X	X	UNIT SHUT DOWN
25	ADANI U-3	65	69	623	520	103	AS PER SYSTEM CONDITION
26	JSW U-1	65	69	245	200	45	AS PER SYSTEM CONDITION

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D.RATES EFFECTIVE FROM 12TH JUNE 2017
- # Indicates that back down withdrawn due to Line loading/system constraints.