

## STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

15-Aug-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS Per MOD
2	TPC U-5	1	96	473	260	213	AS Per MOD
3	JSW U#4 - MSEDCL	X	X	X	X	X	ALREADY TECHNICAL MINIMUM
4	TPC U-8	6	35	235	160	75	AS Per MOD
		44	78				
		92	96				
5	NASIK	9	32	374	310	64	AS Per MOD
		43	78				AS PER SYSTEM CONDITION
		91	96				AS PER SYSTEM CONDITION
6	BHUSAWAL	X	X	X	X	X	NO UNIT ON BAR
7	K'KHEDA U#5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	PARALI U# 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	JSW U#2 (MTOA)	X	X	X	X	X	ALREADY TECHNICAL MINIMUM
10	K'KHEDA U-1,2,3,4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	PARALI U# 7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	PARALI U# 6	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	KORADI	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	CHANDRAPUR	X	X	X	X	X	DC REVISED DUE TO WET COAL
15	PARAS U#3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	REL-G	12	17	479	435	44	AS Per MOD
		48	72	478	336	142	
		93	96	478	336	142	
17	PARAS U#4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
18	JSW U#1	X	X	X	X	X	DC REVISED BY DISCOM
19	AMNEPL-R-INFRA	66	72	50	35	15	AS Per MOD

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Aug-2012.