

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	63	72	496	425	71	DUE TO SYSTEM CONDITION
		73	96	496	283	213	
3	TPC U-8	63	74	235	172	63	DUE TO SYSTEM CONDITION#
		94	96				
4	TPC U-5	63	74	473	292	181	DUE TO SYSTEM CONDITION#
		94	96	473	353	120	
5	PARALI-6	63	96	180	166	14	DUE TO SYSTEM CONDITION
6	PARALI 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	63	96	180	166	14	DUE TO SYSTEM CONDITION
10	REL G	63	74	479	336	143	DUE TO SYSTEM CONDITION#
		94	96				
11	CHANDRAPUR	82	96	1053	976	77	DUE TO SYSTEM CONDITION
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSDDL	70	74	245	172	73	DUE TO SYSTEM CONDITION
		82	96				
14	KHAPERKHEDA-U 1 TO 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	PARAS-3	70	74	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		82	96	201	164	37	DUE TO SYSTEM CONDITION
16	PARAS-4	70	74	182	168	14	DUE TO SYSTEM CONDITION
		82	96	210	168	42	
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	70	74	275	200	75	DUE TO SYSTEM CONDITION
		82	96				

# BACKDOWN NOT IMPLEMENTED IN BLK(82-93) DUE TO MUMBAI EXCHANGE ON A HIGHER SIDE IN REAL TIME SYTEM CONDITIONS.

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Sep.-2013.