

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	SWPL U-1,2,4 TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
2	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
3	TPCU-6	1	96	473	292	181	AS PER SYSTEM CONDITION
4	DTPS REL U-1 AND U-2	1	96	455	336	119	AS PER SYSTEM CONDITION
5	PARALI U-6 AND U-7	X	X	X	X	X	widn for zero schedule as per msedcl
6	PARALI U-8	1	96	229	166	63	AS PER SYSTEM CONDITION
7	BHUSWALU-3	X	X	X	X	X	AS PER SYSTEM CONDITION UNIT-3 ZERO SCHEDULE BY MSEDCL
8	VIPL U-1 AND U-2	1	96	X	X	X	D.C. BELOW TECH. MIN
9	RATTANINDIA U-1 TO U-5	1	96	245	172	73	AS PER SYSTEM CONDITION
10	NASIK U-3,4 AND U-5	1	30	354	283	71	AS PER SYSTEM CONDITION
		31	96	354	283	71	AS PER SYSTEM CONDITION
11	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
12	DHARWAL TO MSEDCL	1	30	X	X	X	D.C. BELOW TECH. MIN
		33	96	X	X	X	D.C. BELOW TECH. MIN
13	JSW U-1	1	30	290	200	90	AS PER SYSTEM CONDITION
		33	72	290	200	90	AS PER SYSTEM CONDITION
		77	96	290	200	90	AS PER SYSTEM CONDITION
14	BHUSWAL U-4 AND U-5	1	30	940	644	296	AS PER SYSTEM CONDITION
		40	72	931	644	287	AS PER SYSTEM CONDITION
		77	96	940	644	296	AS PER SYSTEM CONDITION
15	KORADI U-6, U-7	1	27	X	X	X	UNIT-6 SHUT DOWN UNIT-7 D.C. BELOW TECH MIN
		44	72	X	X	X	UNIT-6 SHUT DOWN UNIT-7 D.C. BELOW TECH MIN
		77	96	X	X	X	UNIT-6 SHUT DOWN UNIT-7 D.C. BELOW TECH MIN
16	KHAERKHEDA U-1 TO U-4	1	27	540	431	109	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		44	66	549	431	118	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		77	96	549	431	118	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
17	PARAS U-3 AND U-4	1	27	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		45	66	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		77	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-5	1	27	428	335	93	AS PER SYSTEM CONDITION
		45	66	437	335	102	AS PER SYSTEM CONDITION
		77	96	466	335	131	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-1 ,A,5(PPA 440MW)	1	27	440	0	440	AS PER SYSTEM CONDITION
		45	51	440	0	440	AS PER SYSTEM CONDITION
		77	96	440	0	440	AS PER SYSTEM CONDITION
21	KORADI U-8,9 AND U-10	1	24	X	X	X	D.C. BELOW TECH. MIN
		78	96	X	X	X	D.C. BELOW TECH. MIN
22	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	24	466	432	34	AS PER SYSTEM CONDITION
		78	96	466	432	34	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	24	466	432	34	AS PER SYSTEM CONDITION
		78	96	466	432	34	AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	24	466	432	34	AS PER SYSTEM CONDITION
		78	96	466	432	34	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-3 TO U-7	1	23	1532	1282	250	AS PER SYSTEM CONDITION
		78	96	1495	1282	213	AS PER SYSTEM CONDITION
26	CHANDRAPUR U-8 AND U-9	1	24	874	656	218	AS PER SYSTEM CONDITION
		78	96	855	656	199	AS PER SYSTEM CONDITION
27	ADANI U-2	1	23	623	432	191	AS PER SYSTEM CONDITION
		90	96	623	432	191	AS PER SYSTEM CONDITION
28	ADANI U-3	1	23	623	432	191	AS PER SYSTEM CONDITION
		90	96	623	432	191	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 11TH NOV. 2018
- 3 # indicates that back down withdrawn due to Line loading/system constraints.