

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	34	483	145	338	AS Per MOD
		84	96	483	145	338	
2	JSW U-4 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs & 21:00 to 24:00 to 190 MW (TECHNICAL MINIMUM)
3	ABHIJIT TO MSEDCL (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 52 TO 35MW (00:00 TO 06:00 HRS & 21:00 TO 24:00 Hrs)
4	TPC U-5	1	27	473	260	213	AS Per MOD
		95	96	473	260	213	
5	TPC U-8	1	25	235	160	75	AS Per MOD
		96	96	235	160	75	
6	JSW U-2 (STOA)	3	22	275	190	85	AS Per MOD
7	REL_G	5	21	480	336	144	AS Per MOD
8	NASHIK	X	X	X	X	X	#
9	BSL	X	X	X	X	X	#
10	PARLI 4	X	X	X	X	X	#
11	PARLI 5	X	X	X	X	X	#
12	K'KHEDA	X	X	X	X	X	#
13	PARLI_ 6	X	X	X	X	X	#
14	PARLI_ 7	X	X	X	X	X	#
15	KORADI	X	X	X	X	X	#
16	CHANDRAPUR	X	X	X	X	X	#

SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 From 19-1-2012, JSW Unit-3 is having CPP transaction with JSW ISPAT for 220 MW RTC, part of the balance power is sold in IEX.

3 Short Term Open Access Contracts of M/s Abhijit are based on station capacity and accordingly Schedule issued to Abhijit is on Station wise basis.

4 MOD rates revised w.e.f 14-Feb-2012.