

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

16-Feb-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT UNDER OUTAGE
2	NASIK	1	32	521	465	56	AS Per MOD
		47	76				DUE TO SYSTEM CONDITION
		89	93				
		94	96				AS Per MOD
3	JSW U2&4 TO MSEDCL	1	31	500	350	150	AS Per MOD
		37	96	X	X	X	DC REVISED BY LM CELL
4	BHUSAWAL-2,3	1	24	161	155	6	AS Per MOD; U 3 UNDER OUTAGE
		29	32				DUE TO SYSTEM CONDITION
		53	76				
5	TPC U-5	1	24	473	260	213	AS Per MOD
		25	28				#
		65	81				DUE TO SYSTEM CONDITION
		89	96				
		29	34	473	366	107	
6	TPC U-8	3	22	235	180	55	AS Per MOD
		23	24				DUE TO SYSTEM CONDITION
		25	28				#
		28	35				DUE TO SYSTEM CONDITION
		65	77				
		89	96				
7	KORADI 5,6,7	3	24	162	155	7	AS Per MOD
		53	58				DUE TO SYSTEM CONDITION
		59	76	288	281	7	DUE TO SYSTEM CONDITION; U#6 SYNC.
8	PARLI 3,4,5	X	X	X	X	X	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
9	REL G	3	24	479	336	143	AS Per MOD
		64	77				DUE TO SYSTEM CONDITION
		94	96	480	460	20	

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
10	BHUSAWAL-4	3	6	420	322	98	DUE TO SYSTEM CONDITION
		7	19				AS Per MOD
		20	24				DUE TO SYSTEM CONDITION
		53	76				
11	K'KHEDA U-1,2,3,4	3	8	690	620	70	DUE TO SYSTEM CONDITION
		9	19				AS Per MOD
		20	24				DUE TO SYSTEM CONDITION
		53	58				
		59	76	545	465	80	DUE TO SYSTEM CONDITION; U3 TRIPPED ON BTL
12	PARALI-6	X	X	X	X	X	UNIT UNDER OUTAGE DUE TO WATER SHORTAGE
13	JSW U-1	4	9	275	190	85	DUE TO SYSTEM CONDITION
		10	18				AS Per MOD
		19	24				DUE TO SYSTEM CONDITION
		53	68				DUE TO SYSTEM CONDITION
14	CHANDRAPUR	5	24	1871	1580	291	DUE TO SYSTEM CONDITION
		54	63	1871	1771	100	
		64	76	1871	1543	328	
15	PARALI-7	10	17	220	164	56	DUE TO SYSTEM CONDITION
16	K'KHEDA U-5	10	24	377	335	42	DUE TO SYSTEM CONDITION

Backing down withdrawn due to line loading constraint on 220kVKalwa- Salsette line due to increasing mumbai demand

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Feb.-2013.