

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	39	96	470	260	210	AS PER SYSTEM CONDITION #
2	TPC U-8	39	96	229	126	103	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	39	96	455	250	205	AS PER SYSTEM CONDITION #
4	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
5	NASIK U-3, U-4 & U-5	1	96	362	204	158	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	APML U-1, U-4 & U-5 (PPA440 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	APML U-1, U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	APML U-1, U-4 & U-5 (PPA 1200 MW)	1	96	1200	1017	183	AS PER SYSTEM CONDITION
12	SWPGL to MSEDCL	1	96	240	132	108	AS PER SYSTEM CONDITION
13	PARAS U-3 & U-4	1	96	227	121	106	AS PER SYSTEM CONDITION/ U-4 OUT
14	DHARIWAL to MSEDCL (Case-IV)	1	7	185	101.75	83.25	AS PER SYSTEM CONDITION
		14	96	185	101.75	83.25	AS PER SYSTEM CONDITION
15	BHUSAWAL U-4 & U-5	1	7	940	518	422	AS PER SYSTEM CONDITION
		16	96	940	518	422	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	1	7	454	309	145	AS PER SYSTEM CONDITION/ U-2 OUT
		18	96	454	309	145	AS PER SYSTEM CONDITION/ U-2 OUT
17	CHANDRAPUR U-3 TO U-7	1	7	900	607	293	AS PER SYSTEM CONDITION/ U-4&7 OUT
		18	96	900	607	293	AS PER SYSTEM CONDITION/ U-4&7 OUT
18	RATTANINDIA U-1 TO U-5	1	5	1200	675	525	AS PER SYSTEM CONDITION
		19	22	1200	675	525	AS PER SYSTEM CONDITION
		28	94	1200	675	525	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	2	5	1330	1023	307	AS PER SYSTEM CONDITION
		28	94	1330	1023	307	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-8 & U-9	2	5	564	518	46	AS PER SYSTEM CONDITION
		29	91	564	518	46	AS PER SYSTEM CONDITION
21	KHAPERKHEDA U-5	2	5	385	256	129	AS PER SYSTEM CONDITION
		29	91	385	256	129	AS PER SYSTEM CONDITION
22	SWPGL to BEST	31	91	100	55	45	AS PER SYSTEM CONDITION
23	APML U-2 & U-3	31	89	623	339	284	AS PER SYSTEM CONDITION/ U-3 OUT
24	JSW U-1	31	88	284	160	124	AS PER SYSTEM CONDITION

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th May 2021