

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

16/07/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	24	445	260	185	AS PER SYSTEM CONDITION #
		29	56	445	260	185	AS PER SYSTEM CONDITION #
		68	79	445	260	185	AS PER SYSTEM CONDITION #
		93	96	445	260	185	AS PER SYSTEM CONDITION #
2	TPC U-8	1	24	220	126	94	AS PER SYSTEM CONDITION #
		29	56	220	126	94	AS PER SYSTEM CONDITION #
		68	79	220	126	94	AS PER SYSTEM CONDITION #
		93	96	220	126	94	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	1	24	222	125	97	AS PER SYSTEM CONDITION # U-1 OUT
		35	78	222	125	97	AS PER SYSTEM CONDITION # U-1 OUT
		95	96	222	125	97	AS PER SYSTEM CONDITION # U-1 OUT
4	NASIK U-3, U-4 & U-5	1	23	185	102	83	AS PER SYSTEM CONDITION# U-3 UNDER CASE IV & U-4 UNDER ZERO SCHEDULE
		35	78	185	102	83	
		95	96	185	102	83	
5	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	PARAS U-3 & U-4	1	23	381	243	138	AS PER SYSTEM CONDITION
		35	78	381	243	138	AS PER SYSTEM CONDITION
		95	96	381	243	138	AS PER SYSTEM CONDITION
11	SWPGL to MSEDCL	1	23	240	132	108	AS PER SYSTEM CONDITION
		35	78	240	132	108	AS PER SYSTEM CONDITION
		96	96	240	132	108	AS PER SYSTEM CONDITION
12	BHUSAWAL U-4 & U-5	2	23	900	518	382	AS PER SYSTEM CONDITION
		41	76	900	518	382	AS PER SYSTEM CONDITION
		96	96	900	518	382	AS PER SYSTEM CONDITION
13	RATTANINDIA U-1 TO U-5	3	20	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		41	73	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
14	APML U-1,U-4 & U-5 (PPA 440 MW)	13	19	426	0	426	AS PER SYSTEM CONDITION
		42	72	426	0	426	AS PER SYSTEM CONDITION
15	CHANDRAPUR U-3 TO U-7	48	72	1203	963	240	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case-IV)	48	72	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	49	67	121	96	25	AS PER SYSTEM CONDITION
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	49	67	1161	921	240	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	51	67	376	256	120	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-8 & U-9	53	66	418	259	159	AS PER SYSTEM CONDITION/ U-9 OUT
21	APML U-2 & U-3	53	61	1246	780	466	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	54	58	1195	952	243	AS PER SYSTEM CONDITION
23	JSW U-1	55	58	290	160	130	AS PER SYSTEM CONDITION
24	SWPGL to BEST	55	58	100	68	32	AS PER SYSTEM CONDITION

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th July 2021