

## STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

16-Nov-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	35	483	145	338	AS Per MOD
		88	96				
		36	41	483	230	253	
		42	51	483	410	73	
		52	81	483	300	183	
		82	87	483	240	243	
2	TPC U-5	1	33	473	260	213	AS Per MOD
		90	96				Due to system condition
3	JSW U4 TO MSEDCL	1	20	275	192.5	82.5	AS Per MOD
		21	96				DC REVISED BY LM CELL,MSEDCL
4	JSW U2 TO MSEDCL	1	22	225	157.5	67.5	AS Per MOD
		23	96				DC REVISED BY LM CELL,MSEDCL
5	NASIK	1	20	486	465	21	AS Per MOD
6	TPC U-8	1	21	235	180	55	AS Per MOD
		90	96				Due to system condition
7	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	KORADI	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI U# 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL-G	1	20	479	336	143	AS Per MOD
11	K'KHEDA U-1,2,3,4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	JSW U#1	5	20	275	190	85	AS Per MOD
13	PARALI U#6	X	X	X	X	X	UNIT NOT ON BAR
14	CHANDRAPUR	5	19	1719	1434	285	AS Per MOD

**Note :**

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.