

SR. NO.	GENERATING STN. / STOA	Backing Down Period (In Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	3	516	425	91	DUE TO SYSTEM CONDITION
		4	28	516	425	91	AS PER MOD
		78	96	516	425	91	DUE TO SYSTEM CONDITION
3	PARALI 3,4,5	1	5	302	276	26	DUE TO SYSTEM CONDITION
		6	28	302	276	26	AS PER MOD
		78	96	302	276	26	DUE TO SYSTEM CONDITION
4	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	X
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	1	5	473	292	181	DUE TO SYSTEM CONDITION
		6	29	473	292	181	AS PER MOD
		80	96	473	292	181	DUE TO SYSTEM CONDITION & LINE LOADING
7	TPC U-8	1	9	235	172	63	DUE TO SYSTEM CONDITION
		10	21	235	172	63	AS PER MOD
		80	96	235	172	63	DUE TO SYSTEM CONDITION & LINE LOADING
8	PARALI-6	1	10	200	166	34	DUE TO SYSTEM CONDITION
		11	16	200	166	34	AS PER MOD
		17	28	200	166	34	DUE TO SYSTEM CONDITION
		78	96	200	166	34	
9	PARALI-7	1	10	200	166	34	DUE TO SYSTEM CONDITION
		11	16	200	166	34	AS PER MOD
		17	28	200	166	34	DUE TO SYSTEM CONDITION
		78	96	200	166	34	
11	REL G	1	10	475	422	53	DUE TO SYSTEM CONDITION
		11	15	475	422	53	AS PER MOD
		16	21	475	422	53	DUE TO SYSTEM CONDITION
		80	96	475	422	53	
12	BHUSAWAL-4	X	X	X	X	X	X
13	KHAPERKHEDE-U5	1	20	427	335	92	DUE TO SYSTEM CONDITION
		80	96	427	335	92	
14	KORADI 5,6,7	X	X	X	X	X	X
15	INDIABULL TO MSDDL	1	20	245	172	73	DUE TO SYSTEM CONDITION
		80	96	245	172	73	
16	CHANDRAPUR	1	20	964	861	103	DUE TO SYSTEM CONDITION
		80	96	964	861	103	
17	KHAPER KHEDA U 1 TO 4	1	20	630	572	58	DUE TO SYSTEM CONDITION
		80	96	630	569	61	
18	JSW U-1	1	20	275	200	75	DUE TO SYSTEM CONDITION
		81	96	275	200	75	
19	ADANI U-1	1	26	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		36	45	617	560	57	
		46	54	617	500	117	
		80	91	617	580	37	
		55	96	617	432	185	
20	PARAS U3	1	20	182	164	18	DUE TO SYSTEM CONDITION
		85	96	182	164	18	
21	PARAS U4	1	20	182	164	18	DUE TO SYSTEM CONDITION
		85	96	182	164	18	
22	JSW TO RINFRA (VIPL)	1	24	134	93.8	40.2	DUE TO SYSTEM CONDITION
23	JSW TO RINFRA (AMNEPL)	88	96	55	38.5	16.5	DUE TO SYSTEM CONDITION
24	ADANI U-2	1	24	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		37	58	617	470	147	
		59	81	617	432	185	
		88	96	617	432	185	
25	ADANI U-3	1	24	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		37	58	617	470	147	
		59	81	617	432	185	
		88	96	617	432	185	

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Dispatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Nov.-2013.