

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TO MSEB FIRM	1	19	200	140	60	AS PER SYSTEM CONDITION
		78	96	200	140	60	AS PER SYSTEM CONDITION
3	TPC U-5	1	19	473	292	181	AS PER SYSTEM CONDITION
		79	96	473	292	181	AS PER SYSTEM CONDITION
4	TPC U-8	1	19	235	187	48	AS PER SYSTEM CONDITION
		79	96	235	187	48	AS PER SYSTEM CONDITION
5	DTPS REL U1 AND U2	1	19	461	336	125	AS PER SYSTEM CONDITION
		80	96	460	336	124	AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	19	364	283	81	AS PER SYSTEM CONDITION
		81	96	162	142	40	NASHIK UNIT-5 TRIPPED AT 4-49HRSAS PER SYSTEM CONDITION
7	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
8	RATTANINDIA U1 TO U-6	1	19	490	344	146	AS PER SYSTEM CONDITION
		81	96	490	344	146	AS PER SYSTEM CONDITION
9	PARLEY U-6 AND U-7	1	19	340	332	8	AS PER SYSTEM CONDITION
		81	96	468	332	126	AS PER SYSTEM CONDITION
10	BHUSWAL U-4 AND U-5	1	19	658	644	14	AS PER SYSTEM CONDITION
		81	96	658	644	14	AS PER SYSTEM CONDITION
11	VIPL U-1 AND U-2	1	19	572	382	190	AS PER SYSTEM CONDITION
		81	96	572	382	190	AS PER SYSTEM CONDITION
12	PARALI U-8	1	19	X	X	X	D.C. BELOW TECH MIN
		81	96	X	X	X	D.C. BELOW TECH MIN
13	KHAPERKHEDA U-1 TO U-4	1	19	438	419	19	UNIT-3 SHUT DOWN ,AS PER SYSTEM CONDITION
		81	96	438	419	19	UNIT-3 SHUT DOWN , AS PER SYSTEM CONDITION
14	PARAS U-3 AND U-4	1	19	460	332	128	AS PER SYSTEM CONDITION
		81	96	460	332	128	AS PER SYSTEM CONDITION
15	ADANI TIRODA 440 PPA	1	18	199	X	X	D.C. BELOW TECH MIN
		81	96	199	X	X	D.C. BELOW TECH MIN
16	KORADI U-6,6,7	X	X	X	X	X	UNIT -6,6,7 SHUTDOWN
17	ADANI U-1 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
18	ADANI U-4 (1200+125)MW PP	1	18	300	X	X	D.C. BELOW TECH MIN
		81	96	300	X	X	D.C. BELOW TECH MIN
19	ADANI U-5 (1200+125)MW PP	1	18	300	X	X	D.C. BELOW TECH MIN
		81	96	300	X	X	D.C. BELOW TECH MIN
20	KHAPERKHEDA U-5	1	18	423	335	88	AS PER SYSTEM CONDITION
		81	96	423	335	88	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	1	18	753	656	97	UNIT-3, UNIT-4 UNIT-5 SHUT DOWNAS PER SYSTEM CONDITION
		81	96	753	656	97	UNIT-3, UNIT-4 UNIT-5 SHUT DOWNAS PER SYSTEM CONDITION
22	KORADI U-8,9,10	1	18	500	432	68	UNIT-8,UNIT-9 SHUT DOWN, BID AS PER SYSTEM CONDITION
		81	96	500	432	68	UNIT-8,UNIT-9 SHUT DOWN,AS PER SYSTEM CONDITION
23	JSW U-1	1	18	281	200	81	AS PER SYSTEM CONDITION
		81	96	281	200	81	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	18	860	658	202	AS PER SYSTEM CONDITION
		81	96	860	658	202	AS PER SYSTEM CONDITION
25	IEPL TO MSEDCCL DA	1	11	X	X	X	D.C. BELOW TECH MIN
		87	96	X	X	X	D.C. BELOW TECH MIN
26	ADANI U-3	1	11	400	X	X	D.C. BELOW TECH MIN
		87	96	400	X	X	D.C. BELOW TECH MIN
27	ADANI U-2	1	11	400	X	X	D.C. BELOW TECH MIN
		87	96	400	X	X	D.C. BELOW TECH MIN

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 H.O.D. RATES REVISED FROM DT. 12TH NOV 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.