

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE:

16/11/2018

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DHARIWAL TO BEST	x	x	x	x	x	50 MW SCHEDULE 33 TO 96 BLOCK
2	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
3	SWPCL U-1.2 AND4 TO MSEDCL	1	96	80	68	12	AS PER SYSTEM CONDITION
4	JSW U-2.3 AND 4 TO MSEDCL	1	96	275	192.5	82.5	AS PER SYSTEM CONDITION
5	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
9	VIPL U-1, U-2	1	96	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
9	DTPS (AEM)U-1 AND U-2	1	36	455	336	119	AS PER SYSTEM CONDITION
		50	96	455	336	119	AS PER SYSTEM CONDITION
10	NASHIK U-3,U-4,U-5	1	29	X	X	X	D.C. TECH MIN
		50	96	315	284	31	AS PER SYSTEM CONDITION
11	BHUSWAL U-3	X	X	X	X	X	UNIT -3 SHUT DOWN
12	RATTANINDIA U-1 TO U-6	1	24	490	344	146	UNIT -3,4,5 SHUT DOWN. AS PER SYSTEM CONDITION
		69	74	490	344	146	UNIT -3,4,5 SHUT DOWN. AS PER SYSTEM CONDITION
		79	96	490	344	146	UNIT -3,4,5 SHUT DOWN. AS PER SYSTEM CONDITION
13	PARALI U-6 AND U-7	1	24	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
		70	74	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
		80	96	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
		1	24	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
14	PARALI U-8	70	74	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
		80	96	229	168	61	AS PER SYSTEM CONDITION unit-7 shut down
		1	24	658	644	14	AS PER SYSTEM CONDITION
15	BHUSWAL U-4 AND U-5	70	74	658	644	14	AS PER SYSTEM CONDITION
		80	96	658	644	14	AS PER SYSTEM CONDITION
		X	X	X	X	X	UNIT 4 AND UNIT-7 SHUT DOWN
17	IEPL TO MSEDCL	X	X	X	X	X	NOSCHEDULE
18	DHARIWAL TO MSEDCL	1	24	x	x	x	RUNING TECH MIN
		80	96	x	x	x	RUNING TECH MIN
19	KHAPERKHEDA U-1 TO U-4	1	24	536	431	105	AS PER SYSTEM CONDITION
		80	96	510	431	79	AS PER SYSTEM CONDITION
20	JSW U-1	1	24	274	200	74	AS PER SYSTEM CONDITION
		80	96	274	200	74	AS PER SYSTEM CONDITION
		1	24	X	X	X	D.C. BELOW TECH MIN
21	KORADI U-8,9,10	80	96	X	X	X	D.C. BELOW TECH MIN
		1	17	475	335	140	AS PER SYSTEM CONDITION
22	KHAPERKHEDA U-5	80	96	399	335	64	AS PER SYSTEM CONDITION
		1	17	X	X	X	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN, UNIT-4 SHUT DOWN
23	PARAS U-3 AND U-4	80	96	X	X	X	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN, UNIT-4 SHUT DOWN
		1	17	440	0	440	AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1,4,5(40PPA)	80	96	440	0	440	AS PER SYSTEM CONDITION
		1	17	1209	988	221	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-3 TO U-7	80	96	1126	988	138	AS PER SYSTEM CONDITION
		1	17	442	432	10	AS PER SYSTEM CONDITION
27	ADANI TIRODA U-1(PPA 1200MW&125MW)	80	96	442	432	10	AS PER SYSTEM CONDITION
		1	17	440	432	8	AS PER SYSTEM CONDITION
28	ADANI TIRODA U-4(PPA 1200MW&125MW)	80	96	440	432	8	AS PER SYSTEM CONDITION
		1	17	442	432	10	AS PER SYSTEM CONDITION
29	ADANI TIRODA U-5(PPA 1200MW&125MW)	80	96	442	432	10	AS PER SYSTEM CONDITION
		1	17	846	656	190	AS PER SYSTEM CONDITION
30	CHANDRAPUR U-8 TO U-9	80	96	846	656	190	AS PER SYSTEM CONDITION
		1	16	623	432	191	AS PER SYSTEM CONDITION
31	ADANI TIRODA U-2	87	96	623	432	191	AS PER SYSTEM CONDITION
		1	16	623	432	191	AS PER SYSTEM CONDITION
32	ADANI TIRODA U-3	87	96	623	432	191	AS PER SYSTEM CONDITION
		1	16	623	432	191	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 15TH NOV. 2018
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.