

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	DHARIWAL TO MSEDCL	1	27	160	140	10	AS PER SYSTEM CONDITION
		34	39	160	140	10	AS PER SYSTEM CONDITION
		70	96	160	140	10	AS PER SYSTEM CONDITION
3	JSW TO MSEDCL	1	27	275	192.5	82.5	AS PER SYSTEM CONDITION
		34	39	275	192.5	82.5	AS PER SYSTEM CONDITION
		70	96	275	192.5	82.5	AS PER SYSTEM CONDITION
4	TPC U-5	1	24	473	292	181	AS PER SYSTEM CONDITION
		35	39	473	365	108	AS PER SYSTEM CONDITION
		70	96	473	292	181	AS PER SYSTEM CONDITION
5	TPC U-8	1	24	230	187	43	AS PER SYSTEM CONDITION
		35	39	230	187	43	AS PER SYSTEM CONDITION
		70	96	230	187	43	AS PER SYSTEM CONDITION
6	DTPS REL U1 AND U2	1	24	460	336	124	AS PER SYSTEM CONDITION
		35	37	461	336	125	AS PER SYSTEM CONDITION
		70	96	460	336	124	AS PER SYSTEM CONDITION
7	NASHIK U-3,4,5	1	24	334	283	51	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		71	89	334	283	51	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
8	RATTANINDIA U-1 TO U-5	1	24	735	516	219	UNIT-4SHUT DOWN, UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		63	96	735	516	219	UNIT-4SHUT DOWN, UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
9	BHUSAWAL U-3	1	23	178	144	34	AS PER SYSTEM CONDITION
		72	75	178	144	34	AS PER SYSTEM CONDITION
		80	88	178	144	34	AS PER SYSTEM CONDITION
10	VIPL U-1 AND U-2	1	23	477	382	95	AS PER SYSTEM CONDITION
		72	75	477	430	47	AS PER SYSTEM CONDITION
		81	88	477	382	95	AS PER SYSTEM CONDITION
11	PARALI U-6 AND U-7	1	23	458	332	126	AS PER SYSTEM CONDITION
		72	75	458	332	126	AS PER SYSTEM CONDITION
		81	88	458	332	126	AS PER SYSTEM CONDITION
12	PARALI U-8	1	23	229	166	63	AS PER SYSTEM CONDITION
		85	88	229	166	63	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	2	940	644	296	AS PER SYSTEM CONDITION
		6	20	940	644	296	AS PER SYSTEM CONDITION
14	PARAS U-3 AND U-4	1	2	460	332	128	AS PER SYSTEM CONDITION
		7	20	460	332	128	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-1 TO U-4	1	2	370	285	85	UNIT-1 AND UNIT-3 SHUT DOWN , AS PER SYSTEM CONDITION
		7	18	370	285	85	UNIT-1 AND UNIT-3 SHUT DOWN , AS PER SYSTEM CONDITION
16	ADANI (TIRODA 640MW PPA) U1,4&5	1	2	440	0	440	AS PER SYSTEM CONDITION
		7	18	440	0	440	AS PER SYSTEM CONDITION
17	ADANI U-1 (1200+125)MW PP	1	2	461	432	29	AS PER SYSTEM CONDITION
		7	18	461	432	29	AS PER SYSTEM CONDITION
18	ADANI U-4 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
19	ADANI U-5(1200+125)MW PP	1	2	461	432	29	AS PER SYSTEM CONDITION
		7	18	461	432	29	AS PER SYSTEM CONDITION
20	KORADI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	KORADI U-8,9 AND U-10	X	X	X	X	X	NO BACK DOWN
23	CHANDRAPUR U-3 TO U-7	X	X	X	X	X	NO BACK DOWN UNIT-3,4,5,7 SHUT DOWN
24	JSW U-1	X	X	X	X	X	SHUT DOWN
25	CHANDRAPUR U-8AND U-9	X	X	X	X	X	NO BACK DOWN
26	ADANI U-2	X	X	X	X	X	UNIT SHUT DOWN
27	ADANI U-3	X	X	X	X	X	NO BACK DOWN

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT-12TH MARCH 2018
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.