

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	SWPCL TO MSECL	X	X	X	X	X	UNIT-4 SHUT DOWN
2	TPC U-6	1	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
4	OTPS REL U-1 AND U-2	1	50	452	336	116	AS PER SYSTEM CONDITION
		51	79	X	X	X	#
		71	96	462	336	116	AS PER SYSTEM CONDITION
5	JSW TO BEST	1	21	89	56	24	AS PER SYSTEM CONDITION
		27	96	89	56	24	AS PER SYSTEM CONDITION
6	NASIK U-3,4 AND 5	1	21	315	284	31	AS PER SYSTEM CONDITION
		27	96	315	284	31	AS PER SYSTEM CONDITION
7	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
8	PARALI U-6 AND U-7	35	96	329	X	X	D.C. BELOW TECH MIN
9	RATTANINDIA U-1 TO U-6	35	78	735	516	219	AS PER SYSTEM CONDITION
		82	91	735	516	219	AS PER SYSTEM CONDITION
10	PARALI U-8	35	78	160	X	X	D.C. BELOW TECH MIN
		82	91	160	X	X	D.C. BELOW TECH MIN
11	BHUSWAL U-4 AND U-5	35	78	940	644	296	AS PER SYSTEM CONDITION
		82	91	940	644	296	AS PER SYSTEM CONDITION
12	IEPL TO MSECL	X	X	X	X	X	UNIT SHUT DOWN
13	DHARWAL TO MSECL	48	78	185	140	45	AS PER SYSTEM CONDITION
		82	91	185	140	45	AS PER SYSTEM CONDITION
14	PARAS U-3 & U-4	43	78	460	332	128	AS PER SYSTEM CONDITION
		82	91	460	332	128	AS PER SYSTEM CONDITION
15	VFPL U1 &2	43	78	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		82	91	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	43	46	270	X	X	D.C. BELOW TECH MIN UNIT-1 AND UNIT-2 SHUT DOWN
		51	78	270	X	X	D.C. BELOW TECH MIN
		82	91	270	X	X	D.C. BELOW TECH MIN
17	ADANI (TROODA 440MW PPA) U1,&5	43	46	X	X	X	D.C. ZERO
		51	78	X	X	X	D.C. ZERO
		82	91	X	X	X	D.C. ZERO
18	KHAPERKHEDA U-5	43	46	333	X	X	D.C. BELOW TECH MIN
		51	78	333	X	X	D.C. BELOW TECH MIN
		83	91	333	X	X	D.C. BELOW TECH MIN
19	KORADI U-6 & U-7	43	46	X	X	X	UNIT 6 AND UNIT-7 SHUT DOWN
		51	78	X	X	X	UNIT 6 AND UNIT-7 SHUT DOWN
		83	91	X	X	X	UNIT 6 AND UNIT-7 SHUT DOWN
20	ADANI U-1(1200+125)MW PP	43	46	525	432	93	AS PER SYSTEM CONDITION
		51	78	525	432	93	AS PER SYSTEM CONDITION
		83	96	525	432	93	AS PER SYSTEM CONDITION
21	ADANI U-4(1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
22	ADANI U-5(1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
23	CHANDRAPUR U-3 TO U-7	51	77	800	660	140	AS PER SYSTEM CONDITION
24	JSW U-1	51	77	290	200	90	AS PER SYSTEM CONDITION
25	KORADI U-8, 9 & U-10	52	77	X	X	X	D.C. BELOW TECH MIN. UNIT-9 SHUT DOWN
26	CHANDRAPUR U-8 & U-9	52	77	867	664	203	AS PER SYSTEM CONDITION
27	ADANI U-2	52	77	525	432	93	AS PER SYSTEM CONDITION
28	ADANI U-3	52	77	525	432	93	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVERSED FROM DT: 12TH JUNE 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.