

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DHARWAL TO BEST	1	25	X	X	X	AS PER SYSTEM CONDITION NO SCHEDULE
		70	72	50	35	15	AS PER SYSTEM CONDITION
		80	96	50	35	15	AS PER SYSTEM CONDITION
2	TPC U-8	1	25	204	187	17	AS PER SYSTEM CONDITION
		70	72	X	X	X	D.C. BELOW TECH MIN
		80	96	X	X	X	D.C. BELOW TECH MIN
3	SWPCL U-1,2 AND4 TO MSEDCCL	1	25	X	X	X	TECH MIN LOAD
		70	72	80	70	10	AS PER SYSTEM CONDITION
		80	96	80	70	10	AS PER SYSTEM CONDITION
4	JSW U-2,3 AND 4TO MSEDCCL	1	25	275	192.5	82.5	AS PER SYSTEM CONDITION
		70	72	275	192.5	82.5	AS PER SYSTEM CONDITION
		80	96	275	192.5	82.5	AS PER SYSTEM CONDITION
5	TPC U-5	1	23	473	292	181	AS PER SYSTEM CONDITION
		70	72	473	315	168	AS PER SYSTEM CONDITION
		80	96	473	292	181	AS PER SYSTEM CONDITION
6	VPL U-1, U-2	1	23	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		70	72	286	224	62	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
		80	96	286	191	95	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
7	DTPS (AEM)U-1 AND U-2	1	23	456	336	120	AS PER SYSTEM CONDITION
		70	72	456	336	120	AS PER SYSTEM CONDITION
		80	96	456	336	120	AS PER SYSTEM CONDITION
8	NASHIK U-3,U-4,U-5	1	23	300	284	16	AS PER SYSTEM CONDITION
		81	96	325	284	41	AS PER SYSTEM CONDITION
9	BHUSWAL U-3	x	x	x	x	x	UNIT -3 SHUT DOWN
10	RATTANINDIA U-1 TO U-5	1	20	480	344	146	UNIT -3,4,5 SHUT DOWN. AS PER SYSTEM CONDITION
		81	96	480	344	146	UNIT -3,4,5 SHUT DOWN. AS PER SYSTEM CONDITION
11	PARALI U-6 AND U-7	1	20	229	166	63	AS PER SYSTEM CONDITION unit-7 shut down
		83	96	229	166	63	AS PER SYSTEM CONDITION unit-7 shut down
12	PARALI U-8	1	20	229	166	63	AS PER SYSTEM CONDITION
		83	96	229	166	63	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	20	656	644	12	AS PER SYSTEM CONDITION
		83	96	656	644	12	AS PER SYSTEM CONDITION
14	KORADI U-6 AND U-7	X	X	X	X	X	UNIT-6 SYN. TRIPPED D.C. BELOW TECH MINAND UNIT-7 SHUT DOWN
15	IEPL TO MSEDCCL	X	X	X	X	X	NOSCHEDULE
16	DHARWAL TO MSEDCCL	1	20	X	X	X	RUNING TECH MIN
		83	96	X	X	X	RUNING TECH MIN
17	KHAPEKHEDE U-1 TO U-4	1	20	351	284	67	unit-1 and unit-3 shut down AS PER SYSTEM CONDITION
		83	96	351	284	67	unit-1 and unit-3 shut down AS PER SYSTEM CONDITION
18	JSW U-1	1	20	274	200	74	AS PER SYSTEM CONDITION
		83	96	274	200	74	AS PER SYSTEM CONDITION
19	KORADI U-8,9,10	1	17	X	X	X	D.C. BELOW TECH MIN
		83	96	X	X	X	D.C. BELOW TECH MIN
20	KHAPEKHEDE U-5	1	17	475	335	140	AS PER SYSTEM CONDITION
		83	96	456	335	121	AS PER SYSTEM CONDITION
21	PARAS U-3 AND U-4	1	17	X	X	X	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN, UNIT-4 SHUT DOWN
22	ADANI TIRODA U-1,4,5(440PPA)	1	17	440	0	440	AS PER SYSTEM CONDITION
23	CHANDRAPUR U-3 TO U-7	1	8	1365	1126	229	unit-4 shut down AS PER SYSTEM CONDITION
24	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	8	442	432	10	AS PER SYSTEM CONDITION
25	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	8	440	432	8	AS PER SYSTEM CONDITION
26	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	8	442	432	10	AS PER SYSTEM CONDITION
27	CHANDRAPUR U-8 TO U-9	1	8	423	328	95	unit-8 shut downAS PER SYSTEM CONDITION
28	ADANI TIRODA U-2	X	X	X	X	X	NO BACK DOWN
29	ADANI TIRODA U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Backdown variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 112TH NOV. 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.