

SR. NO.	GENERATING STN. / STO A	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
2	DTPS U-1 & U-2	1	27	453	336	117	AS PER SYSTEM CONDITION
		32	36	453	336	117	AS PER SYSTEM CONDITION #
		83	96	453	336	117	AS PER SYSTEM CONDITION
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
5	PARAS U-3 & U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
6	JSW TO AEML_DA	1	27	132.66	92.86	39.80	AS PER SYSTEM CONDITION
		32	71	132.66	92.86	39.80	AS PER SYSTEM CONDITION
		75	96	132.66	92.86	39.80	AS PER SYSTEM CONDITION
7	TPC U-5	1	26	473	292	181	AS PER SYSTEM CONDITION
		35	71	473	292	181	AS PER SYSTEM CONDITION
		75	96	473	292	181	AS PER SYSTEM CONDITION
8	TPC U-8	1	26	X	X	X	DC TECH MIN
		35	71	X	X	X	DC TECH MIN
		75	96	X	X	X	DC TECH MIN
9	NASHIK U-3, U-4 & U-5	1	26	172	141	31	U-5 UNDER ZERO SCHEDULE & U-3 UNDER CASE-IV
		36	67	172	141	31	
		76	96	172	141	31	
10	RATTANINDIA U-1 TO U-5	X	X	X	X	X	U-1 OUT & U-2,3,4&5 UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	1	25	378	283	95	AS PER SYSTEM CONDITION/ U-1&2 UNDER ZERO SCHEDULE
		36	65	378	283	95	
		76	96	378	283	95	
12	BHUSAWAL U-4 & U-5	1	25	846	644	202	AS PER SYSTEM CONDITION
		37	65	846	644	202	AS PER SYSTEM CONDITION
		76	96	846	644	202	AS PER SYSTEM CONDITION
13	KHAPERKHEDA U-5	1	25	475	335	140	AS PER SYSTEM CONDITION
		37	65	475	335	140	AS PER SYSTEM CONDITION
		80	96	475	335	140	AS PER SYSTEM CONDITION
14	PARALI U-6 & U-7	1	25	458	332	126	AS PER SYSTEM CONDITION
		37	63	458	332	126	AS PER SYSTEM CONDITION
		80	96	458	332	126	AS PER SYSTEM CONDITION
15	CHANDRAPUR U-3 TO U-7	1	25	968	808	160	AS PER SYSTEM CONDITION/ U-4&7 OUT
		37	63	968	808	160	AS PER SYSTEM CONDITION/ U-4&7 OUT
		80	96	968	808	160	AS PER SYSTEM CONDITION/ U-4&7 OUT
16	PARALI U-8	1	25	229	166	63	AS PER SYSTEM CONDITION
		37	63	229	166	63	AS PER SYSTEM CONDITION
		80	96	229	166	63	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-8 & U-9	1	24	921	656	265	AS PER SYSTEM CONDITION
		40	63	921	656	265	AS PER SYSTEM CONDITION
		80	96	921	656	265	AS PER SYSTEM CONDITION
18	DHARIWAL TO MSEDCL(CASE IV)	1	24	X	X	X	DC TECH MIN
		40	63	X	X	X	DC TECH MIN
		80	96	X	X	X	DC TECH MIN
19	APML U-1,U-4&U-5 (PPA440 MW)	1	23	440	0	440	AS PER SYSTEM CONDITION
		41	45	440	0	440	AS PER SYSTEM CONDITION
		49	55	440	0	440	AS PER SYSTEM CONDITION
		81	96	440	0	440	AS PER SYSTEM CONDITION
20	KORADI U-8 TO U-10	1	23	1592	1296	296	AS PER SYSTEM CONDITION
		41	45	1592	1296	296	AS PER SYSTEM CONDITION
		50	55	1592	1296	296	AS PER SYSTEM CONDITION
		81	96	1592	1296	296	AS PER SYSTEM CONDITION
21	APML U-1,U-4&U-5 (PPA1200MW,125 MW)	1	23	1325	1296	29	AS PER SYSTEM CONDITION
		41	44	1325	1296	29	AS PER SYSTEM CONDITION
		50	55	1325	1296	29	AS PER SYSTEM CONDITION
		81	96	1325	1296	29	AS PER SYSTEM CONDITION
22	JSW U-1	1	22	275	200	75	AS PER SYSTEM CONDITION
		41	44	275	200	75	AS PER SYSTEM CONDITION
		50	53	275	200	75	AS PER SYSTEM CONDITION
		83	96	275	200	75	AS PER SYSTEM CONDITION
23	ADANI U-2 & U-3	14	19	1246	1060	186	AS PER SYSTEM CONDITION

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- # Indicates that back down withdrawn due to Line loading/system constraints.
- Revised MOD Rates effective from 00:00 HRS of 12th Nov 2019