18-Jan-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down	
		FROM	то	Declared Capacity (A)	Targat Despatched Schedule (Min) (B)	Quantum [Max] in MW [A-B]	REMARK
		1	39				AS Per MOD
1	TPC U-6	40	48	483	145	338	DUE TO SYSTEM CONDITION
		49	96				AS Per MOD
	NASIK	1	32	516	465	51	AS Per MOD
2		35	48				DUE TO SYSTEM CONDITION
		49	96				AS Per MOD
	APML(TIRODA) - MSEDCL	1	31	Х	Х	Χ	DC REVISED BY LM CELL
3		32	32	475	432	43	AS Per MOD
		43	96	Х	Х	Х	DC REVISED BY LM CELL
4	JSW U2&4 TO MSEDCL	1	32	300	233	67	AS Per MOD
		43	96	Х	Х	Х	DC REVISED BY LM CELL
5	TPC U-5	1	32	473	260	213	AS Per MOD
5		67	96				
	TPC U-8	1	30	230	180	50	AS Per MOD
6		68	73				
		90	96				
	BHUSAWAL-2,3	1	29	322	310	12	AS Per MOD
7		69	72				
		91	96				
8	KORADI 5,6,7	Х	Х	Х	Х	Х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
	REL G	1	29	479	336	143	AS Per MOD
9		69	72	479	435	44	
		91	96	480	336	144	
10	PARLI 3,4,5	Х	Х	Х	Х	Х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	BHUSAWAL-4	1	24	400	322	78	AS Per MOD
10	K'KHEDA U-1,2,3,4	1	23	670	620	50	AS Per MOD
12		24	24				DUE TO SYSTEM CONDITION
13	JSW U-1	1	24	275	190	85	AS Per MOD
14	PARALI-6	1	22	225	164	61	AS Per MOD
14		23	24	225	181	44	DUE TO SYSTEM CONDITION
15	CHANDRAPUR	1	20	1824	1537	287	AS Per MOD
		21	24				DUE TO SYSTEM CONDITION

16	PARALI-7	Х	Х	Х	Х	Х	UNIT UNDER OUTAGE
17	K'KHEDA-5	1	7	425	335	90	DUE TO SYSTEM CONDITION
		8	19				AS Per MOD
		20	24				DUE TO SYSTEM CONDITION
	AMNEPL TO REL	5	8	45	38	7	DUE TO SYSTEM CONDITION
18		9	19				AS Per MOD
		20	24				DUE TO SYSTEM CONDITION
	PARAS-4	5	8	230	164	66	DUE TO SYSTEM CONDITION
19		9	19				AS Per MOD
		20	24				DUE TO SYSTEM CONDITION
	PARAS-3	5	9	230	164	66	DUE TO SYSTEM CONDITION
20		10	18				AS Per MOD
		19	24				DUE TO SYSTEM CONDITION
21	JSW 2&4 TO REL	10	18	96	67	29	AS Per MOD
22	WPCL TO REL	10	18	256	195	61	AS Per MOD

Note:

¹ Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

² MOD rates revised w.e.f 12-Jan.-2013.