

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DHARIWAL TO TPC_D	13	18	82.16	45.18	36.98	AS PER SYSTEM CONDITION
		81	90	82.16	45.18	36.98	AS PER SYSTEM CONDITION
2	TPC U-5	13	17	470	270	200	AS PER SYSTEM CONDITION *
		81	90	470	270	200	AS PER SYSTEM CONDITION *
3	TPC U-8	X	X	X	X	X	NO BACK DOWN #
4	DTPS U-1 & U-2	X	X	X	X	X	NO BACK DOWN #
5	KORADI U-6 & U-7	81	90	288	206	82	AS PER SYSTEM CONDITION
6	NASIK U-3, U-4 & U-5	81	90	185	102	83	AS PER SYSTEM CONDITION */ U-4 OUT & U-3 UNDER CASE IV
7	SWPGL to MSEDCL	X	X	X	X	X	NO BACK DOWN
8	BHUSAWAL U-3	X	X	X	X	X	NO BACK DOWN
9	PARALI U-8	X	X	X	X	X	NO BACK DOWN
10	DHARIWAL to MSEDCL (Case-IV)	X	X	X	X	X	NO BACK DOWN
11	PARALI U-6 & U-7	X	X	X	X	X	NO BACK DOWN
12	APML U-1, U-4 & U-5 (PPA440 MW)	X	X	X	X	X	NO BACK DOWN
13	RATTANINDIA U-1 TO U-5	X	X	X	X	X	NO BACK DOWN
14	APML U-1, U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	NO BACK DOWN
15	APML U-1, U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	NO BACK DOWN
16	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	NO BACK DOWN
17	CHANDRAPUR U-3 TO U-7	X	X	X	X	X	NO BACK DOWN
18	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
19	BHUSAWAL U-4 & U-5	X	X	X	X	X	NO BACK DOWN
20	PARAS U-3 & U-4	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	UNIT OUT
25	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN

## Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 \* Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th Mar 2021