

STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

18-Jun-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Target Dispatched Schedule (Min) (B)		
1	TPC U-6	1	42	483	145	338	AS PER MOD
		43	49	483	230	253	
		50	96	483	145	338	
2	GEPL TO TPC	37	40	70	49	21	AS PER MOD
		53	84				
3	NASIK	1	40	516	425	91	AS PER MOD
		53	78				
4	BHUSAWAL 2.3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	1	30	473	292	181	AS PER MOD
		56	57	473	450	23	
		66	77	473	292	181	DUE TO SYSTEM CONDITION
6	TPC U-8	1	26	235	172	63	AS PER MOD
		67	74				
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	REL G	1	25	478	336	142	AS PER MOD
		67	73				
9	BHUSAWAL 4	X	X	X	X	X	UNIT UNDER OUTAGE
10	K'KHEDA U-1,2,3,4	1	21	437	403	34	AS PER MOD
		69	73	X	X	X	DC REVISED DUE TO PCO
11	INDIABULL TO MSEDCL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	CHANDRAPUR	1	20	1273	1259	14	AS PER MOD
		69	73	X	X	X	DC REVISED DUE TO PCO
13	K'KHEDA U-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	PARAS-3	1	20	230	164	66	AS PER MOD
		71	73	172	164	8	
15	PARAS-4	2	20	230	168	62	AS PER MOD
		73	73	201	190	11	
16	JSW U-1	3	20	275	200	75	AS PER MOD
17	ABHURT TO RINFRA	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
18	VIPL TO RINFRA	4	19	134	93.8	40.2	AS PER MOD
19	APML (U 3) TO MSEDCL	5	19	617	432	185	AS PER MOD
20	APML (U 1) TO MSEDCL	15	17	617	608	9	AS PER MOD

**Note :**

<sup>1</sup> Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State-Merit Order Dispatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

<sup>2</sup> MOD rates revised w.e.f 12-June-2013.