

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							18-Jul-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	REL DAHANU U1 AND U2	1	24	464	336	128	AS PER SYSTEM CONDITION
		49	64	X	X	X	#
		65	78	464	336	128	AS PER SYSTEM CONDITION
		83	96	464	336	128	AS PER SYSTEM CONDITION
3	NASHIK	1	24	192	142	50	AS PER SYSTEM CONDITION
		49	78	192	142	50	AS PER SYSTEM CONDITION
		83	96	192	142	50	AS PER SYSTEM CONDITION
4	TPC U-8	1	24	235	187	48	AS PER SYSTEM CONDITION
		49	75	235	187	48	AS PER SYSTEM CONDITION
		83	96	235	187	48	AS PER SYSTEM CONDITION
5	BHUSWAL U2,3	X	X	X	X	X	UNIT-2 SHUT DOWN, UNIT-3 WIDN FOR ZERO SCHEDULE BY MSEDCL
6	TPC U-5	1	24	473	292	181	AS PER SYSTEM CONDITION
		49	75	473	292	181	AS PER SYSTEM CONDITION
		84	96	473	292	181	AS PER SYSTEM CONDITION
7	RATTANINDIA U-1,2,3,4,5	X	X	X	X	X	UNIT-1,2,3,4,5 WIDN FOR ZERO SCHEDULE BY MSEDCL
8	PARLEY U-6 AND U-7	X	X	X	X	X	UNIT-7 and UNIT-6 FOR ZERO SCHEDULE BY MSEDCL AS PER SYSTEM CONDITION
9	PARLEY U-8	X	X	X	X	X	UNIT-8 WIDN FOR ZERO SCHEDULE BY MSEDCL
10	KHAPERKHEDA U1 TO U4	X	X	X	X	X	2,3,4 SHUT DOWN, UNIT-1 WIDN FOR ZERO SCHEDULE BY MSEDCL
11	KORADI U5 TO U7	X	X	X	X	X	UNIT-5 , UNIT-6 SHUT DOWN UNIT -7 SHUT DOWN
12	BHUSWAL U-4 AND U-5	X	X	X	X	X	CONDITION UNIT-5,UNIT-4WIDN FOR ZERO SCHEDULE BY MSEDCL
13	VIPL U1,2	1	24	286	191	95	UNITT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		51	75	286	191	95	UNITT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		85	96	286	191	95	UNITT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-5	1	15	470	335	135	AS PER SYSTEM CONDITION
		51	75	470	335	135	AS PER SYSTEM CONDITION
		85	96	470	335	135	AS PER SYSTEM CONDITION
15	KORADI U8 ,U9,10	1	15	X	X	X	D.C . BELOW TECH MIN. UNIT-8 TRIPPED AT 1:25HRS AND SYN 5:57HRS
		51	75	1066	1024	42	UNIT-10 TRIPPED AT 1:02HRS AND SYN. 8:35HRSAS PER SYSTEM CONDITION
		85	96	1066	1024	42	SAS PER SYSTEM CONDITION
16	PARAS U-3 ANDU-4	1	25	460	332	128	AS PER SYSTEM CONDITION
		35	75	460	332	128	AS PER SYSTEM CONDITION
		85	96	460	332	128	AS PER SYSTEM CONDITION
17	ADANI 440 PPA	1	24	440	0	440	AS PER SYSTEM CONDITION
		51	57	440	0	440	AS PER SYSTEM CONDITION
		58	68	137	0	137	AS PER SYSTEM CONDITION
		69	74	440	0	440	AS PER SYSTEM CONDITION
		87	96	440	0	440	AS PER SYSTEM CONDITION
18	ADANI U-1(1200MW &125MW PPA)	1	24	468	432	36	AS PER SYSTEM CONDITION
		51	74	468	432	36	AS PER SYSTEM CONDITION
		87	96	468	432	36	AS PER SYSTEM CONDITION
19	ADANI U-4(1200MW &125MW PPA)	1	24	468	432	36	AS PER SYSTEM CONDITION
		51	74	468	432	36	AS PER SYSTEM CONDITION
		87	96	468	432	36	AS PER SYSTEM CONDITION
20	ADANI U-5(1200MW &125MW PPA)	1	24	468	432	36	AS PER SYSTEM CONDITION
		51	74	468	432	36	AS PER SYSTEM CONDITION
		87	96	468	432	36	AS PER SYSTEM CONDITION
21	CHANDRAPUR U3 TO U7	1	6	1433	1134	299	AS PER SYSTEM CONDITION
		51	70	1433	1134	299	AS PER SYSTEM CONDITION
22	CHANDRAPUR U8 AND U9	1	6	948	658	290	AS PER SYSTEM CONDITION
		51	70	948	658	290	AS PER SYSTEM CONDITION
23	ADANI UNIT-2	1	5	623	435	188	AS PER SYSTEM CONDITION
		61	65	623	450	173	AS PER SYSTEM CONDITION
24	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
25	JSW U-1	1	5	282	200	82	AS PER SYSTEM CONDITION
		62	65	282	200	82	AS PER SYSTEM CONDITION

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES EFFECTIVE FROM 12TH JULY 2017
- # Indicates that back down withdrawn due to Line loading/system constraints.