

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	29	496	425	71	AS Per MOD
		30	50	X	X	X	U 3,4 5 TRIPPED DUE TO BUS BAR OPERATED AT NASIK OCR
		59	72	162	141	21	DUE TO SYSTEM CONDITION , U 3 & 5 SYN.
		84	96	294	273	21	
3	TPC U-8	1	32	235	172	63	AS Per MOD
		60	72				DUE TO SYSTEM CONDITION
		84	96				
4	TPC U-5	1	32	473	292	181	AS Per MOD
		60	72				DUE TO SYSTEM CONDITION
		90	96				
5	PARALI-6	7	27	180	166	14	AS Per MOD
		41	56	200	166	34	DUE TO SYSTEM CONDITION
		61	72				
		91	96				
6	PARALI 3,4,5	8	26	145	138	7	AS Per MOD
		41	56				DUE TO SYSTEM CONDITION
		61	72				
		91	96				
7	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI-7	8	26	180	166	14	AS Per MOD
		41	56	200	166	34	DUE TO SYSTEM CONDITION
		61	72				
		91	96				
10	REL G	8	24	477	336	141	AS Per MOD
		41	56				DUE TO SYSTEM CONDITION
		61	72				
		91	96				
11	CHANDRAPUR	9	20	1333	1198	135	AS Per MOD
		41	48				DUE TO SYSTEM CONDITION
		49	72	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		91	96	1064	1033	31	DUE TO SYSTEM CONDITION
12	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	INDIABULL TO MSDDL	13	18	245	172	73	AS Per MOD
		42	56				DUE TO SYSTEM CONDITION
		67	72				
		91	86				
14	KHAPERKHEDA-U 1 TO 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	PARAS-3	X	X	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
16	PARAS-4	1	72	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCQ
		91	96	191	168	23	DUE TO SYSTEM CONDITION
17	KHAPERKHEDA-5	X	X	X	X	X	UNIT UNDER OUTAGE
18	JSW U 1	67	72	275	200	75	AS Per MOD
		92	96				DUE TO SYSTEM CONDITION
19	AMNEPL TO REL	68	68	53	37	16	DUE TO SYSTEM CONDITION
		69	72	40	37	3	
		92	93				
20	APML U 2 TO MSEDCL	67	72	617	540	77	DUE TO SYSTEM CONDITION
		92	96	617	500	117	
21	APML U 3 TO MSEDCL	67	72	617	540	77	DUE TO SYSTEM CONDITION
		92	96	617	500	117	

TPC U 8 , U 5 IN BLK (41-56) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Sep.-2013.