

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

18-Nov-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS Per MOD
2	TPC U-5	1	35	473	260	213	AS Per MOD
		88	96				Due to system condition
		43	87				
		36	42	473	300	173	AS Per MOD
3	JSW U4 TO MSEDCL	1	34	275	192.5	82.5	AS Per MOD
		42	96	X	X	X	DC REVISED BY LM CELL,MSEDCL
4	JSW U2 TO MSEDCL	1	32	225	157.5	67.5	AS Per MOD
		42	96	X	X	X	DC REVISED BY LM CELL,MSEDCL
5	NASIK	1	31	516	465	51	AS Per MOD
		70	96	486	465	21	Due to system condition
6	TPC U-8	1	30	235	180	55	AS Per MOD
		79	96	235	180	55	Due to system condition
7	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		85	96	174	155	19	Due to system condition
8	KORADI	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
9	PARALI U# 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	REL-G	1	21	479	336	143	AS Per MOD
		85	96				Due to system condition
11	K'KHEDA U-1,2,3,4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	JSW U#1	1	20	275	190	85	AS Per MOD
		85	96				Due to system condition
13	PARALI U#6	X	X	X	X	X	UNIT NOT ON BAR
14	CHANDRAPUR	5	19	1348	1179	169	AS Per MOD
		84	96	1415	1223	192	Due to system condition
15	PARALI U#7	6	17	200	164	36	AS Per MOD
		85	96				Due to system condition
16	K'KHEDA U-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
17	PARAS-3,4	7	17	364	328	36	AS Per MOD
		85	96	334	316	18	Due to system condition
18	AMNEPL - R-INFRA	9	17	50	35	15	AS Per MOD

Note :

¹ Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.