

SR. NO.	GENERATING STN. / STOA	Backing Down Period (In Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	35	344	283	61	AS PER MOD
		46	46	X	X	X	B/D W/D DUE TO SYSTEM CONDITION
		50	50	X	X	X	
		54	56	X	X	X	
		69	74	344	283	61	AS PER MOD
		77	96	344	283	61	
3	PARALI 3,4,5	1	31	302	276	26	AS PER MOD
		69	73	302	276	26	
		77	96	302	276	26	
4	JSW U 2,4 TO BEST(100 MW)	69	72	100	70	30	AS PER MOD
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	1	31	473	292	181	AS PER MOD
		66	87	X	X	X	B/D W/D DUE TO SYSTEM CONDITION
		88	96	473	292	181	AS PER MOD
7	TPC U-8	1	22	235	172	63	AS PER MOD
		70	72	235	172	63	B/D W/D DUE TO SYSTEM CONDITION
		89	96	235	172	63	DUE TO SYSTEM CONDITION
8	PARALI-6	1	20	200	166	34	AS PER MOD
		89	96	200	166	34	DUE TO SYSTEM CONDITION
9	PARALI-7	1	20	200	166	34	AS PER MOD
		89	96	200	166	34	DUE TO SYSTEM CONDITION
11	REL G	1	20	475	336	139	AS PER MOD
		89	96	475	336	139	DUE TO SYSTEM CONDITION
12	BHUSAWAL-4	X	X	X	X	X	X
13	KHAPERKHEDE-U5	1	20	475	335	140	AS PER MOD
		89	96	380	335	45	DUE TO SYSTEM CONDITION
14	KORADI 5,6,7	X	X	X	X	X	X
15	INDIABULL TO MSEDCL	1	4	245	172	73	DUE TO SYSTEM CONDITION
		5	20	245	172	73	AS PER MOD
		89	96	245	172	73	DUE TO SYSTEM CONDITION
16	CHANDRAPUR	1	5	1350	1206	144	DUE TO SYSTEM CONDITION
		6	20	1350	1206	144	AS PER MOD
		89	96	1350	1206	144	DUE TO SYSTEM CONDITION
17	KHAPER KHEDA U 1 TO 4	1	10	632	572	60	DUE TO SYSTEM CONDITION
		11	20	632	572	60	AS PER MOD
		89	96	632	572	60	DUE TO SYSTEM CONDITION
18	JSW U-1	1	20	275	200	75	DUE TO SYSTEM CONDITION
		89	95	275	200	75	
19	ADANI U-1	1	20	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		21	88	617	432	185	
		89	96	617	432	185	
20	PARAS U3	1	20	182	164	18	DUE TO SYSTEM CONDITION
21	PARAS U4	1	20	182	164	18	DUE TO SYSTEM CONDITION
22	JSW TO RINFRA (AMNEPL)	1	20	55	38.5	16.5	DUE TO SYSTEM CONDITION
23	JSW TO RINFRA (VIPL)	1	20	134	110	24	DUE TO SYSTEM CONDITION
24	ADANI U-2	1	70	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		89	96	617	432	185	
25	ADANI U-3	1	70	617	432	185	DUE TO SYSTEM CONDITION, SPS OPERATED
		89	96	617	432	185	
26	JSW 2&4 to RINFRA	X	X	X	X	X	X
27	WPCL TO RINFRA	1	20	209	160	49	DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Nov-2013.