

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							18-Nov-15
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TATA U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	1	62	576	425	151	AS PER SYSTEM CONDITION
		68	96	576	425	151	AS PER SYSTEM CONDITION
3	VIPL U1&U-2	1	61	546	382	164	AS PER SYSTEM CONDITION
		68	96	546	382	164	AS PER SYSTEM CONDITION
4	PARLI U-3,4,5	X	X	X	X	X	UNIT SHUT DOWN
5	CHANDRAPUR	1	23	1415	1087	328	AS PER SYSTEM CONDITION
		24	26	1835	1419	416	AS PER SYSTEM CONDITION AND U5 SYN AT 5:35 HRS
		27	38	1415	1087	328	AS PER SYSTEM CONDITION AND U5 TRPPED AT 6:35 HRS
		39	61	1835	1419	416	AS PER SYSTEM CONDITION AND U5 SYN AT 9:22 HRS
		68	96	1835	1419	416	AS PER SYSTEM CONDITION
6	PARLI U-6,7	X	X	X	X	X	UNIT SHUT DOWN
7	REL DAHANU U1AND U2	1	28	470	336	134	AS PER SYSTEM CONDITION
		48	59	470	336	134	AS PER SYSTEM CONDITION
		69	96	470	336	134	AS PER SYSTEM CONDITION
8	KORADI	1	27	162	155	7	U-5 DC BELOW TECH MIN AND UNIT-6 SHUT DOWN
		48	59	162	155	7	
		70	96	162	155	7	
9	BHUSWALU2,3	1	27	308	288	20	AS PER SYSTEM CONDITION
		48	59	308	288	20	AS PER SYSTEM CONDITION
		70	96	X	X	X	U-2 & 3 TRIPPED AT 13:54 HRS
10	RATAN INDIA U-1,U-2 ,U-3 ,4,5	1	27	1180	860	320	AS PER SYSTEM CONDITION
		48	57	1180	860	320	AS PER SYSTEM CONDITION
		70	96	1180	860	320	AS PER SYSTEM CONDITION
11	TPC U-5	1	26	455	292	163	AS PER SYSTEM CONDITION
		77	84	455	360	95	AS PER SYSTEM CONDITION
		85	96	455	292	163	AS PER SYSTEM CONDITION
12	TPCU-8	1	26	235	187	48	AS PER SYSTEM CONDITION
		77	91	X	X	X	#
		92	96	235	192	43	AS PER SYSTEM CONDITION
13	KHAPERKHEDA U1 ,U2,U3,U4	1	25	701	572	129	AS PER SYSTEM CONDITION
		77	96	701	572	129	AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-5	1	27	475	335	140	AS PER SYSTEM CONDITUION
		77	96	475	335	140	AS PER SYSTEM CONDITION
15	BHUSWAL U-4 AND U-5	1	25	940	644	296	AS PER SYSTEM CONDITION
		77	96	940	644	296	AS PER SYSTEM CONDITION
16	PARAS U-3 AND U-4	1	25	X	X	X	U-3 DC BELOW TECH MIN AND U-4 SHUTDOWN
		77	96	210	168	42	AS PER SYSTEM CONDITION and U-4 SHUTDOWN
17	ADANI U-5	1	25	611	432	179	AS PER SYSTEM CONDITION
		77	96	611	432	179	AS PER SYSTEM CONDITION
18	ADANI U-4	X	X	X	X	X	UNIT SHUT DOWN
19	ADANI U-1	1	25	611	432	179	AS PER SYSTEM CONDITION
		77	96	585	432	153	AS PER SYSTEM CONDITION
20	JSW U-1	1	25	290	200	90	AS PER SYSTEM CONDITION
		78	96	290	200	90	AS PER SYSTEM CONDITION
21	ADANI U-3	1	25	623	432	191	AS PER SYSTEM CONDITION
		78	96	623	432	191	AS PER SYSTEM CONDITION
22	ADANI U-2	1	25	623	432	191	AS PER SYSTEM CONDITION
		78	96	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-NOV-2015.

3 # Indicates that back down withdrawn due to Line loading/system constraints.