

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 19-Feb-17 |
|--|------------------------------|-------------------------------|----|------------------------------------|-------------------------------|--|--|
| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum (Max) in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) /BL | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUTDOWN |
| 2 | NASHIK | 1 | 25 | 364 | 283 | 81 | UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL , B/D AS PER SYSTEM CONDITION |
| | | 65 | 96 | 364 | 283 | 81 | UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL , B/D AS PER SYSTEM CONDITION |
| 3 | REL DHANU U1AND U2 | 1 | 25 | 466 | 336 | 130 | AS PER SYSTEM CONDITION |
| | | 65 | 96 | 468 | 336 | 132 | AS PER SYSTEM CONDITION |
| 4 | TPC U8 | 1 | 25 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| | | 65 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 5 | TPCU5 | 1 | 25 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 65 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 6 | RATTANINDIA U1,2,3,4,5 | X | X | X | X | X | UNIT-1,2,3,4,5 W/DNFOR ZERO SCHEDULE BY MSEDCL |
| 7 | BHUSWAL U- 2,3 | 1 | 25 | X | X | X | UNIT-2 W/DN FOR ZERO SCHEDULEBY MSEDCL UNIT-3 RUNNING AT TECH MIN. TO MEET SYSTEM CONSTRIANT |
| | | 66 | 96 | X | X | X | UNIT-2 W/DN FOR ZERO SCHEDULEBY MSEDCL UNIT-3 RUNNING AT TECH MIN. TO MEET SYSTEM CONSTRIANT |
| 8 | KORADI U-5 TO U-7 | X | X | X | X | X | UNIT-6 SHUT DOWN, UNL5 SHUT DOWN, UNIT-7 W/DN FOR ZERO SCHEDULE BY MSEDCL AT 14:18HRS. ON 15/02/2017 |
| 9 | KHAPERKHEDA U1 TO U4 | 1 | 20 | 648 | 572 | 76 | AS PER SYSTEM CONDITION |
| | | 66 | 96 | 648 | 572 | 76 | AS PER SYSTEM CONDITION |
| 10 | BHUSWAL U-4AND U-5 | 1 | 20 | 950 | 644 | 306 | AS PER SYSTEM CONDITION |
| | | 66 | 96 | 950 | 644 | 306 | AS PER SYSTEM CONDITION |
| 11 | KHAPERKHEDA U-5 | 1 | 20 | 480 | 335 | 145 | AS PER SYSTEM CONDITION |
| | | 66 | 96 | 480 | 335 | 145 | AS PER SYSTEM CONDITION |
| 12 | VIPL U1,2 | 1 | 20 | 273 | 191 | 82 | U-1 SHUTDOWN AND BD AS PER SYSTEM CONDITION |
| | | 67 | 96 | 273 | 191 | 82 | U-1 SHUTDOWN AND BD AS PER SYSTEM CONDITION |
| 13 | PARLY U-8 | X | X | X | X | X | UNIT SHUT DOWN |
| 14 | PARLEY U-6 AND U-7 | 1 | 20 | 458 | 332 | 126 | AS PER SYSTEM CONDITION |
| | | 67 | 96 | 458 | 332 | 126 | AS PER SYSTEM CONDITION |
| 15 | PARAS U3 AND U-4 | 1 | 20 | 230 | 168 | 62 | UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION |
| | | 67 | 96 | 230 | 168 | 62 | UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION |
| 16 | CHANDRAPUR U3 TO U7 | 1 | 20 | 1227 | 954 | 273 | UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION |
| | | 67 | 96 | 1227 | 954 | 273 | UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION |
| 17 | ADANI 440 PPA | 72 | 96 | 261.008 | 78.008 | 183 | AS PER SYSTEM CONDITION |
| 18 | ADANI U-1 | X | X | X | X | X | UNIT-1 SHUT DOWN |
| 19 | ADANI U-4(1200MW &125MW PPA) | 72 | 96 | 392.62 | X | X | D.C. BELOW TECH MIN |
| 20 | ADANI U-5(1200MW &125MW PPA) | 72 | 96 | 392.62 | X | X | D.C. BELOW TECH MIN |
| 21 | CHANDRAPUR U8AND U9 | 72 | 96 | 886 | 658 | 228 | AS PER SYSTEM CONDITION |
| 22 | KORADI U8 ,U9,10 | 73 | 90 | 905 | 789 | 116 | UNIT-10 SHUT DOWN AS PER SYSTEM CONDITION |
| 23 | ADANI UNIT-2 | X | X | X | X | X | NO BACK DOWN |
| 24 | ADANI U-3 | X | X | X | X | X | NO BACK DOWN |
| 25 | JSW U-1 | X | X | X | X | X | UNIT SHUT DOWN |

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES EFFECTIVE FROM 16TH FEB 2016 (REV R2)
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.