

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							19-May-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASHIK	1	96	546	425	121	AS PER SYSTEM CONDITION
3	REL DAHANU U1 AND U2	1	96	464	336	128	AS PER SYSTEM CONDITION
4	TPCU-8	1	96	235	167	48	AS PER SYSTEM CONDITION
5	TPC U-5	1	96	473	292	161	AS PER SYSTEM CONDITION
6	JSW TO RINFRA DA	1	40	X	X	X	NO SCHEDULE
		41	96	62	43	19	AS PER SYSTEM CONDITION
7	RATTANINDIA U1,2,3,4,5	1	96	546	382	164	U-4 & 5 SHUTDOWN; BD AS PER SYSTEM CONDITION
8	BHUSWAL U2,3	1	96	X	X	X	UNIT-3 D.C TECH MIN UNIT-2 SHUT DOWN
9	KORADI U-5 TO U-7	1	96	X	X	X	unit-7 running below tech min UNIT-5 AND UNIT-6 SHUT DOWN
10	DHARWAL TO MSEB	1	9	150	140	10	AS PER SYSTEM CONDITION
		28	96	150	140	10	AS PER SYSTEM CONDITION
11	VIPL U1 AND U2	1	8	546	382	164	AS PER SYSTEM CONDITION
		28	96	546	382	164	AS PER SYSTEM CONDITION
12	PARLEY U-8	1	7	170	166	4	AS PER SYSTEM CONDITION
		28	40	170	166	4	AS PER SYSTEM CONDITION
		41	42	X	X	X	UNIT- TRIPPED AT 9:56HRS
		49	61	X	X	X	UNIT- TRIPPED AT 9:56HRS
		62	96	170	166	4	UNIT SYN. AT 15:06HRSAS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	7	944	644	300	AS PER SYSTEM CONDITION
		28	42	944	644	300	AS PER SYSTEM CONDITION
		49	96	944	644	300	AS PER SYSTEM CONDITION
14	PARLEY U-6,7	1	7	458	332	126	AS PER SYSTEM CONDITION
		30	42	458	332	126	AS PER SYSTEM CONDITION
		49	96	458	332	126	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U1 TO U4	1	7	708	572	136	UNIT-4 shut down BIDAS PER SYSTEM CONDITION
		30	35	638	572	66	UNIT-4 shut down BIDAS PER SYSTEM CONDITION
		49	96	638	572	66	UNIT-4 shut down BIDAS PER SYSTEM CONDITION
16	KHAPERKHEDA U-5	1	7	400	335	65	AS PER SYSTEM CONDITION
		30	35	361	335	26	AS PER SYSTEM CONDITION
		51	96	380	335	45	AS PER SYSTEM CONDITION
17	KORADI U8 ,U9,10	1	7	1569	1240	329	AS PER SYSTEM CONDITION
		30	35	1569	1240	329	AS PER SYSTEM CONDITION
		54	96	1569	1240	329	AS PER SYSTEM CONDITION
18	PARAS U-3 ANDU-4	1	7	460	332	128	AS PER SYSTEM CONDITION
		54	89	460	332	128	AS PER SYSTEM CONDITION
		90	96	230	168	62	UNIT-3 TRIPPED AT 22:14AS PER SYSTEM CONDITION B/D AS PER SYSTEM CONDITION
19	ADANI 440 PPA	1	7	X	X	X	D.C. BELOW TECH MIN
		54	96	X	X	X	D.C. BELOW TECH MIN
20	ADANI U-1(1200MW &125MW PPA)	1	7	X	X	X	D.C. BELOW TECH MIN
		54	96	X	X	X	D.C. BELOW TECH MIN
21	ADANI U-4(1200MW &125MW PPA)	1	7	X	X	X	D.C. BELOW TECH MIN
		54	96	X	X	X	D.C. BELOW TECH MIN
22	ADANI U-4(1200MW &125MW PPA)	1	7	X	X	X	D.C. BELOW TECH MIN
		54	96	X	X	X	D.C. BELOW TECH MIN
23	CHANDRAPUR U3 TO U7	1	5	1225	954	271	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
		63	91	1225	954	271	AS PER SYSTEM CONDITION UNIT-7 SHUT DOWN
24	CHANDRAPUR U8 AND U9	63	91	758	658	100	AS PER SYSTEM CONDITION
25	ADANI UNIT-2	64	90	X	X	X	D.C. BELOW TECH MIN
26	ADANI U-3	64	90	X	X	X	D.C. BELOW TECH MIN
27	JSW U-1	64	90	230	200	30	AS PER SYSTEM CONDITION

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D.RATES EFFECTIVE FROM 12TH AS May-17
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.