

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	21	470	260	210	AS PER SYSTEM CONDITION #
		39	42	470	260	210	AS PER SYSTEM CONDITION #
2	TPC U-8	1	21	229	126	103	AS PER SYSTEM CONDITION #
		39	42	229	126	103	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	1	20	455	250	205	AS PER SYSTEM CONDITION #
		39	40	455	250	205	AS PER SYSTEM CONDITION #
4	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
5	NASIK U-3, U-4 & U-5	1	20	177	102	75	AS PER SYSTEM CONDITION# U-3 UNDER
		40	81	177	102	75	CASE IV & U-5 UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	APML U-1,U-4 & U-5 (PPA440 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	APML U-1,U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	APML U-1,U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
12	SWPGL to MSEDCL	1	19	169	132	37	AS PER SYSTEM CONDITION
		43	80	169	132	37	AS PER SYSTEM CONDITION
13	PARAS U-3 & U-4	1	19	430	243	187	AS PER SYSTEM CONDITION
		44	80	430	243	187	AS PER SYSTEM CONDITION
14	DHARIWAL to MSEDCL (Case-IV)	1	19	185	101.75	83.25	AS PER SYSTEM CONDITION
		44	80	185	101.75	83.25	AS PER SYSTEM CONDITION
15	BHUSAWAL U-4 & U-5	44	59	895	518	377	AS PER SYSTEM CONDITION
		64	74	895	518	377	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	45	56	277	207	70	AS PER SYSTEM CONDITION/ U-2&4 OUT
		64	74	277	207	70	AS PER SYSTEM CONDITION/ U-2&4 OUT
17	CHANDRAPUR U-3 TO U-7	45	56	876	607	269	AS PER SYSTEM CONDITION/ U-4&7 OUT
		64	73	876	607	269	AS PER SYSTEM CONDITION/ U-4&7 OUT
18	RATTANINDIA U-1 TO U-5	64	71	1200	675	525	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	NO BACK DOWN

## Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 \* Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th May 2021