

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							19-Jun-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	JSW TO RINFRA DA	X	X	X	X	X	B/D. VARIABLE SCHEDULE BLK 1T03 AND 81 TO 96
3	NASHIK	1	39	364	284	80	B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
		45	73	X	X	X	# B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
		74	96	364	284	80	B/D AS PER SYSTEM CONDITION, UNIT-5 CONVERTED TO ZEROSCHEDULE BY MSEDCL
4	REL DAHANU U1 AND U2	1	42	464	336	128	AS PER SYSTEM CONDITION
		45	96	464	336	128	AS PER SYSTEM CONDITION
5	TPC U-8	1	40	235	187	48	AS PER SYSTEM CONDITION
		41	73	X	X	X	#
		74	90	235	187	48	AS PER SYSTEM CONDITION
6	TPC U-5	1	40	473	292	181	AS PER SYSTEM CONDITION
		41	90	X	X	X	#
7	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	unit-2, UNIT-5 W/DN , UNIT-4 W/DN RS FOR ZERO SCHEDULE BY MSEDCL. UNIT-1 AND UNIT-3 SHUT DOWN
8	BHUSWAL U2,3	X	X	X	X	X	UNIT-2 SHUT DOWN, UNIT-3 W/DN FOR ZERO SCHEDULE BY MSEDCL
9	PARLEY U-6 AND U-7	X	X	X	X	X	UNIT-7 and UNIT-6 FOR ZERO SCHEDULE BY MSEDCL AS PER SYSTEM CONDITION
10	PARLEY U-8	X	X	X	X	X	UNIT-8 W/DN FOR ZERO SCHEDULE BY MSEDCL
11	BHUSWAL U-4 AND U-5	1	40	940	644	296	AS PER SYSTEM CONDITION
		45	96	940	644	296	AS PER SYSTEM CONDITION
12	KHAPERKHEDA U1 TO U4	1	40	X	X	X	UNIT-2 SHUT DOWN ,D.C. BELOW TECH MIN
		59	96	X	X	X	UNIT-2 SHUT DOWN ,D.C. BELOW TECH MIN
13	KORADI-5,6,7	1	40	X	X	X	UNIT-5, UNIT-6 SHUT DOWN UNIT -7 RUNNING BELOW TECH MIN
		59	96	X	X	X	UNIT-5, UNIT-6 SHUT DOWN UNIT -7 RUNNING BELOW TECH MIN
14	VIPL U1,2	2	23	286	191	95	UNIT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		33	40	286	191	95	UNIT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		59	96	286	191	95	UNIT-1 SHUT DOWN, B/D AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-5	2	23	475	335	140	AS PER SYSTEM CONDITION
		33	40	475	335	140	AS PER SYSTEM CONDITION
		59	76	475	335	140	AS PER SYSTEM CONDITION
		83	96	475	335	140	AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	2	23	X	X	X	D.C. BELOW TECH MIN
		33	40	X	X	X	D.C. BELOW TECH MIN
		59	76	X	X	X	D.C. BELOW TECH MIN
		83	96	X	X	X	D.C. BELOW TECH MIN
17	PARAS U-3 AND U-4	2	23	460	332	128	AS PER SYSTEM CONDITION
		33	40	460	332	128	AS PER SYSTEM CONDITION
		59	76	460	332	128	AS PER SYSTEM CONDITION
		83	96	460	332	128	AS PER SYSTEM CONDITION
18	ADANI 440 PPA	4	22	304	0	304	AS PER SYSTEM CONDITION
		59	76	409	0	409	AS PER SYSTEM CONDITION
		83	90	409	0	409	AS PER SYSTEM CONDITION
19	CHANDRAPUR U3 TO U7	6	22	1276	988	288	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		61	76	1276	988	288	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		83	84	1276	988	288	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
20	ADANI U-1(1200MW &125MW PPA)	6	22	X	X	X	UNIT SHUT DOWN
		61	76	458	432	26	UNIT SYN. AT 11:24HRSAS PER SYSTEM CONDITION
		83	84	458	432	26	AS PER SYSTEM CONDITION
21	ADANI U-4(1200MW &125MW PPA)	6	22	458	432	26	AS PER SYSTEM CONDITION
		61	76	458	432	26	AS PER SYSTEM CONDITION
		83	84	458	432	26	AS PER SYSTEM CONDITION
22	ADANI U-5(1200MW &125MW PPA)	6	22	458	432	26	AS PER SYSTEM CONDITION
		61	76	458	432	26	AS PER SYSTEM CONDITION
		83	84	458	432	26	AS PER SYSTEM CONDITION
23	CHANDRAPUR U8 AND U9	6	18	474	329	145	UNIT-8 SHUT DOWN AS PER SYSTEM CONDITION
		68	76	474	329	145	UNIT-8 SHUT DOWN AS PER SYSTEM CONDITION
24	ADANI UNIT-2	12	17	623	432	191	AS PER SYSTEM CONDITION
		69	76	623	432	191	AS PER SYSTEM CONDITION
25	ADANI U-3	12	17	623	432	191	AS PER SYSTEM CONDITION
		69	76	623	432	191	AS PER SYSTEM CONDITION
26	JSW U-1	73	76	245	200	45	AS PER SYSTEM CONDITION

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D RATES EFFECTIVE FROM 12TH JUNE 2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.