10	10	m	110

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in		Backing Down Quantum [Max] in MW [A-B]	REMARK
SK. NU.		FROM	то	Declared Capacity (A)	Despatched Schedule (Min) (B) X		
1	JSW U-2,3,4 TO AEML	1	21	300	210	90	AS PER SYSTEM CONDITION
		47	58	300	210	90	AS PER SYSTEM CONDITION
		85	96	300	210	90	AS PER SYSTEM CONDITION
2	DTPS U-1 AND U-2	1	21	455	336	119	AS PER SYSTEM CONDITION #
		93	96	455	336	119	AS PER SYSTEM CONDITION #
3 1	TPC U-8	1	21	205	187	18	AS PER SYSTEM CONDITION #
	IPC 0-8	93	96	205	187	18	AS PER SYSTEM CONDITION #
4	BHUSAWAL U-3	X	Х	Х	Х	X	UNIT UNDER ZERO SCHEDULE
5	VIPL U-1 AND U-2	X	Х	Х	Х	X	UNIT-1 AND UNIT-2 SHUT DOWN
6	TPC U-5	1	21	460	292	168	AS PER SYSTEM CONDITION #
7	KORADI U-6 AND U-7	Х	Х	Х	Х	Х	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	Х	Х	Х	Х	Х	UNIT SHUT DOWN
9	NASHIK U-3,4,5	1	21	177	142	35	AS PER SYSTEM CONDITION # /U-3,5 UNDER ZERO SCHEDULE
10	PARALI U-6 AND U-7	Х	Х	Х	Х	Х	UNIT SHUT DOWN
11	RATTANINDIA U-1 TO U-5	3	21	735	516	219	U-2 UNDER ZERO SCHEDULE & U-5 OUT
		47	58	735	516	219	
12	BHUSAWAL U-4 AND U-5	16	19	776	644	132	AS PER SYSTEM CONDITION
13	CHANDRAPUR U-3 TO U-7	16	19	979	930	49	AS PER SYSTEM CONDITION/U-7 OUT
14	KORADI U-8 TO U-10	16	19	X	X	X	DC TECH MIN/ U-9 OUT
15	PARAS U-3 AND U-4	16	19	458	328	130	AS PER SYSTEM CONDITION
16	CHANDRAPUR U-8 AND U-9	16	19	668	634	34	AS PER SYSTEM CONDITION
17	ADANI TIRODA U-1,4,5 (PPA440 MW)	х	х	х	х	x	NO BACK DOWN
18	ADANI TIRODA U-1,4,5 (PPA1200MW,125 MW)	х	х	х	х	х	NO BACK DOWN
19	JSW U-1	X	х	Х	Х	Х	NO BACK DOWN
20	KHAPERKHEDA U-1 TO U-4	X	х	Х	X	Х	NO BACK DOWN
21	KHAPERKHEDA U-5	X	Х	Х	Х	Х	NO BACK DOWN
22	ADANI U-2 & U-3	X	Х	Х	Х	Х	NO BACK DOWN

- Note:

 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

 MOD RATES REVISED FROM 15:00HRS OF 16TH APRIL2019 AS PER OLD PROCEDURE Stayed Due to Hon'ble APPELLATE TRIBUNAL order in IA No. 593 of 2019 in DFR No.1762 of 2019 in Hodicates that back down withdrawn due to Line loading/system constraints.

 REVISED MOD RATES EFFECTIVE FROM 00:00HRS 12TH AUG 2019