

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							19-Oct-16
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASIK	1	24	364	284	80	UNIT-5W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		47	56	364	284	80	UNIT-5W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
		90	96	364	284	80	UNIT-5W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION
3	REL DAHANU U 1&2	1	24	467	336	131	AS PER SYSTEM CONDITION
		47	52	467	336	131	AS PER SYSTEM CONDITION
		90	96	467	336	131	AS PER SYSTEM CONDITION
4	BHUSWAL U-2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE
5	RATTANINDIA U1 TO U5	X	X	X	X	X	UNIT-1,2,3,4,5ZERO SCHEDULE BY MSEDCL
6	TPC U8	1	23	235	187	48	AS PER SYSTEM CONDITION
		93	96	235	187	48	AS PER SYSTEM CONDITION
7	TPC U5	1	23	473	292	181	AS PER SYSTEM CONDITION
		93	96	473	292	181	AS PER SYSTEM CONDITION
8	VIPL U1&2	1	23	546	382	164	AS PER SYSTEM CONDITION
		93	96	546	382	164	AS PER SYSTEM CONDITION
9	BHUSWAL U-4 &U-5	X	X	X	X	X	MSEDCL W/DN UNIT -4,5 FOR ZERO SCHEDULE
10	KORADI U5 TO U7	93	96	X	X	X	UNIT-6 SHUT DOWN UNI-5 SHUT DOWN AND UNIT-7 SYN. AT18:46HRS D.C BELOW TECH MIN TRIPPED AT19:07HRS
11	PARLEY U-6 AND U-7	12	15	229	166	63	UNIT-6 SYN.AT2:48HRSD AS PER SYSTEM CONDITION
		16	23	329	266	63	UNIT-6 SYN.AT2:48HRSD AS PER SYSTEM CONDITION
		93	96	458	332	126	UNIT-6 SYN.AT2:48HRSD AS PER SYSTEM CONDITION
12	KHAPERKHEDA U1 TO U4	7	22	742	572	170	AS PER SYSTEM CONDITION
		93	96	742	572	170	AS PER SYSTEM CONDITION
13	CHANDRAPUR U3 TO U7	7	22	1607	1282	325	AS PER SYSTEM CONDITION UNIT-1 SYN.
		94	96	1607	1282	325	AS PER SYSTEM CONDITION
14	PARAS U-3 AND U-4	7	22	230	168	62	UNIT-4SHUT DOWN B/DAS PER SYSTEM CONDITION
		94	96	230	168	62	UNIT-4 SHUT DOWN B/DAS PER SYSTEM CONDITION
15	KHAPERKHEDA U5	7	21	475	335	140	AS PER SYSTEM CONDITION
16	ADANI U1	7	21	466.33	432	34.33	AS PER SYSTEM CONDITION
17	ADANI U4	7	21	466.33	432	34.33	AS PER SYSTEM CONDITION
18	ADANI U5	7	21	466.33	432	34.33	AS PER SYSTEM CONDITION
19	CHANDRAPUR U8	7	21	474	329	145	AS PER SYSTEM CONDITION
20	KORADIU8	7	21	X	X	X	D.C BELOW TECH MIN
21	ADANI U-2	X	X	X	X	X	NO BACK DOWN
22	ADANI U-3	X	X	X	X	X	NO BACK DOWN
23	JSW U-1	X	X	X	X	X	NO BACK DOWN
X							

NOTE:

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM 12TH OF OCT. 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.