

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: 20-Jan-14							
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	x	x	x	x	x	ECONOMY SHUTDOWN
2	NASIK	1	27	516	425	91	AS PER MOD
		33	64	516	428	88	
		70	71	516	485	31	
		83	96	516	425	91	
3	PARALI-3,4,5	1	25	322	276	46	AS PER MOD
		84	96	322	276	46	
4	JSW TO RINFRA DA (JSWPTC)	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	BHUSAWAL-2,3	x	x	x	x	x	
6	BHUSAWAL U4	1	24	400	322	78	AS PER MOD
		85	96	400	322	78	
7	TPC U-5	1	22	473	292	181	AS PER MOD
		85	96	473	292	181	
8	PARLY U-6	1	22	230	166	64	AS PER MOD
		89	96	230	166	64	
9	TPC U-8	x	x	x	x	x	UNIT SHUTDOWN
10	PARLY U-7	2	21	230	166	64	AS PER MOD
		89	96	230	166	64	
11	KORADI	4	20	315	308	7	AS PER MOD
		89	96	315	308	7	
12	REL_G	4	20	237	167	70	AS PER MOD
		89	96	237	167	70	
13	KHAPERKHEDA U5	5	20	423	335	88	AS PER MOD
		89	96	423	335	88	
14	KHAPER KHEDA U 1 TO 4	9	19	508	429	79	AS PER MOD
		92		508	483	25	
		96		508	498	10	
15	BHUSAWAL U5	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	CHANDRAPUR	9	18	1253	1074	179	AS PER MOD

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 12-Jan.-2013.