

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							20-Mar-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) /B/		
1	TPC U-6	X	X	X	X	X	UNIT SHUTDOWN
2	NASHIK	1	96	364	284	80	UNIT-5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITIN
3	TPC U-8	1	45	235	187	48	AS PER SYSTEM CONDITION
		67	96	235	187	48	AS PER SYSTEM CONDITION
4	TPCU5	1	45	473	292	181	AS PER SYSTEM CONDITION
		67	96	473	292	181	AS PER SYSTEM CONDITION
5	DTPS REL U-1AND U-2	1	43	468	336	132	AS PER SYSTEM CONDITION
		67	96	468	336	132	AS PER SYSTEM CONDITION
6	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	UNIT-1,2,3,4,5 W/DN FOR ZERO SCHEDULE BY MSEDCL
7	BHUSWAL U-2,3	X	X	X	X	X	UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULEBY MSEDCL
8	KORADI U-5 TO U-7	X	X	X	X	X	UNIT-6 SHUT DOWN, UNI-5 SHUT DOWN ,UNIT-7 W/DN FOR ZERO SCHEDULE BY MSEDCL AT 14:18HRS. ON 15/02/2017
9	KHAPERKHEDA U1 TO U4	X	X	X	X	X	UNIT-2 SHUT DOWN, UNIT-1, UNIT-3 UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL, B/D AS PER SYSTEM CONDITION
10	BHUSWAL U-4AND U-5	1	21	950	644	306	AS PER SYSTEM CONDITION
		30	41	950	644	306	AS PER SYSTEM CONDITION
		74	76	950	644	306	AS PER SYSTEM CONDITION
		85	96	950	644	306	AS PER SYSTEM CONDITION
11	PARLYU-6 AND U-7	1	21	458	332	126	AS PER SYSTEM CONDITION
		30	41	458	332	126	AS PER SYSTEM CONDITION
		74	76	458	332	126	AS PER SYSTEM CONDITION
		85	96	458	332	126	AS PER SYSTEM CONDITION
12	KHAPERKHEDA U-5	1	21	475	335	140	AS PER SYSTEM CONDITION
		30	41	475	335	140	AS PER SYSTEM CONDITION
		74	76	475	335	140	AS PER SYSTEM CONDITION
		85	96	475	335	140	AS PER SYSTEM CONDITION
13	PARLY U-8	1	21	X	X	X	UNIT SHUTDOWN
		85	96	X	X	X	RUNNING BELOW TECH MIN. UNIT SYN. AT 20:45HRS.AS PER SYSTEM CONDITION
14	PARAS U3 AND U-4	1	21	460	332	128	AS PER SYSTEM CONDITION
		85	96	460	332	128	AS PER SYSTEM CONDITION
15	VIPL U1 AND U2	1	21	473	292	181	AS PER SYSTEM CONDITION
		85	96	473	292	181	AS PER SYSTEM CONDITION
16	KORADI U8 ,U9,10	1	21	954	761	193	UNIT-10 SHUT DOWN , B/D AS PER SYSTEM CONDITION
		85	96	973	780	193	UNIT-10 SHUT DOWN , B/D AS PER SYSTEM CONDITION
17	ADANI 440 PPA	3	21	440	0	440	AS PER SYSTEM CONDITION
		85	96	440	68	372	AS PER SYSTEM CONDITION
18	ADANI U-1(1200MW &125MW PPA)	9	20	432	X	X	D.C . TECH MIN. B/D AS PER SYSTEM CONDITION
19	ADANI U-4(1200MW &125MW PPA)	9	20	432	X	X	D.C . TECH MIN. B/D AS PER SYSTEM CONDITION
20	ADANI U-5(1200MW &125MW PPA)	9	20	432	X	X	D.C . TECH MIN. B/D AS PER SYSTEM CONDITION
21	CHANDRAPUR U3 TO U7	12	12	1202	954	248	AS PER SYSTEM CONDITION
22	CHANDRAPUR U8 AND U9	12	12	682	658	24	AS PER SYSTEM CONDITION
23	ADANI UNIT-2	X	X	X	X	X	NO BACK DOWN
24	ADANI U-3	X	X	X	X	X	NO BACK DOWN
25	JSW U-1	X	X	X	X	X	NO BACK DOWN

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES EFFECTIVE FROM 12TH MARCH 2017
- # Indicates that back down withdrawn due to Line loading/system constraints.